

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
JANUARY 2025

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.39	0.08	1.01	1.31	0.12	51	7.2	0.7	0.92	0	KD
2	1.31	0.09	0.95	1.27	0.10	53	7.2	0.6	1.04	0	KD
3	1.37	0.10	1.04	1.30	0.11	52	7.2	0.7	1.10	0	KD
4	1.36	0.08	0.92	1.30	0.11	53	7.3	0.8	1.00	0	RC
5	1.32	0.09	0.98	1.21	0.12	52	7.3	0.8	0.91	0	RC
6	1.39	0.07	0.90	1.15	0.12	52	7.2	0.7	1.03	0	KD
7	1.37	0.08	0.94	1.33	0.10	50	7.3	0.7	1.00	0	KD
8	1.36	0.08	0.94	1.26	0.11	51	7.2	0.7	0.98	0	RC
9	1.48	0.08	1.08	1.25	0.10	51	7.2	0.8	0.96	0	RC
10	1.26	0.08	1.15	1.31	0.09	50	7.3	0.7	1.09	0	RC
11	1.48	0.04	1.25	1.25	0.10	50	7.2	0.8	1.11	0	RC
12	1.32	0.09	1.38	1.10	0.12	51	7.3	0.8	1.22	0	RC
13	1.33	0.07	1.41	1.38	0.12	50	7.3	0.8	1.27	0	RC
14	1.29	0.08	1.19	1.22	0.11	49	7.3	0.8	1.29	0	RC
15	1.36	0.09	1.26	1.30	0.10	47	7.3	0.8	1.16	0	AM
16	1.39	0.09	1.29	1.30	0.10	48	7.2	0.8	1.21	0	AM
17	1.31	0.10	1.28	1.28	0.11	48	7.1	0.8	1.19	0	AM
18	1.35	0.08	1.33	1.38	0.12	50	7.1	0.7	1.23	0	JS
19	1.28	0.09	1.36	1.13	0.14	49	7.1	0.8	1.28	0	AM
20	1.33	0.08	1.27	1.11	0.11	49	7.0	0.8	1.19	0	AM
21	1.36	0.10	1.29	1.13	0.11	48	7.0	0.8	1.26	0	AM
22	1.39	0.08	1.30	1.40	0.10	50	7.0	0.8	1.35	0	JS
23	1.35	0.07	1.35	1.48	0.09	49	7.0	0.8	1.35	0	JS
24	1.37	0.06	1.65	1.39	0.09	50	7.1	0.8	1.66	0	JS
25	1.45	0.08	1.41	1.41	0.08	49	7.1	0.8	1.29	0	AM
26	1.40	0.07	1.36	1.40	0.09	48	7.1	0.8	1.27	0	AM
27	1.36	0.06	1.36	1.41	0.11	50	7.0	0.7	1.17	0	JS
28	1.35	0.07	1.37	1.42	0.10	50	7.0	0.8	1.26	0	JS
29	1.40	0.07	1.30	1.39	0.11	52	7.0	0.7	1.34	0	JS
30	1.37	0.08	1.28	1.40	0.10	50	7.1	0.8	1.27	0	AM
31	1.36	0.08	1.37	1.30	0.09	49	7.1	0.9	1.33	0	AM
AVG.	1.36	0.08	1.22	1.30	0.11	50	7.2	0.8	1.18	0	
MAX.	1.48	0.10	1.65	1.48	0.14	53	7.3	0.9	1.66	0	
MIN.	1.26	0.04	0.90	1.10	0.08	47	7.0	0.6	0.91	0	

 2/5/25  
Mike Weed, Operations Supervisor Date  
Illinois ROINC # 186860234

DUPAGE WATER COMMISSION  
 PWS FACILITY ID# - IL435400  
 MONTHLY OPERATIONS REPORT  
 DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
 FEBRUARY 2025

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.33	0.09	1.29	1.44	0.09	50	7.1	0.8	1.34	0	JS
2	1.31	0.10	1.31	1.39	0.09	49	7.1	0.8	1.37	0	JS
3	1.35	0.08	1.27	1.28	0.09	50	7.0	0.7	1.29	0	AM
4	1.32	0.07	1.42	1.27	0.10	48	7.1	0.7	1.38	0	JS
5	1.43	0.09	1.45	1.40	0.09	47	7.0	0.8	1.24	0	JS
6	1.38	0.06	1.28	1.37	0.09	48	7.1	0.7	1.44	0	JS
7	1.41	0.06	1.40	1.40	0.10	47	7.0	0.7	1.32	0	JS
8	1.39	0.07	1.41	1.38	0.09	47	7.0	0.8	1.35	0	KD
9	1.46	0.08	1.21	1.20	0.14	49	7.0	0.8	1.35	0	KD
10	1.42	0.07	1.26	1.43	0.09	48	7.0	0.6	1.31	0	JS
11	1.41	0.08	1.54	1.29	0.09	49	7.0	0.6	1.37	0	JS
12	1.52	0.05	1.31	1.25	0.90	47	7.0	0.6	1.49	0	KD
13	1.49	0.07	1.35	1.12	0.52	48	7.1	0.6	1.31	0	KD
14	1.41	0.06	1.35	1.41	0.14	41	7.0	0.7	1.36	0	KD
15	1.43	0.05	1.31	1.35	0.09	40	7.2	0.6	1.22	0	RC
16	1.44	0.05	1.56	1.09	0.16	47	7.2	0.6	1.31	0	RC
17	1.39	0.05	1.56	1.09	0.14	45	7.2	0.5	1.53	0	KD
18	1.36	0.05	1.43	1.05	0.14	45	7.1	0.6	1.49	0	KD
19	1.42	0.05	1.46	1.23	0.11	44	7.1	0.6	1.60	0	RC
20	1.42	0.05	1.47	1.38	0.07	42	7.1	0.6	1.46	0	RC
21	1.38	0.06	1.49	1.22	0.10	47	7.1	0.5	1.52	0	RC
22	1.43	0.06	1.57	1.28	0.08	46	7.1	0.5	1.52	0	KD
23	1.42	0.06	1.35	1.10	0.12	49	7.0	0.5	1.48	0	KD
24	1.27	0.06	1.43	1.30	0.12	50	7.1	0.6	1.48	0	RC
25	1.26	0.07	1.46	1.21	0.07	41	7.1	0.6	1.36	0	RC
26	1.27	0.07	1.33	1.07	0.10	47	7.1	0.5	1.40	0	KD
27	1.41	0.08	1.50	1.19	0.08	50	7.0	0.5	1.35	0	KD
28	1.37	0.05	1.36	1.18	0.11	47	7.0	0.6	1.48	0	KD
29											
30											
31											

AVG.	1.39	0.07	1.40	1.26	0.15	47	7.1	0.6	1.40	0
MAX.	1.52	0.10	1.57	1.44	0.90	50	7.2	0.8	1.60	0
MIN.	1.26	0.05	1.21	1.05	0.07	40	7.0	0.5	1.22	0

 3/5/25  
 Mike Weed, Operations Supervisor Date  
 Illinois ROINC # 186860234