


DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
JANUARY 2025

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.39	0.08	1.01	1.31	0.12	51	7.2	0.7	0.92	0	KD
2	1.31	0.09	0.95	1.27	0.10	53	7.2	0.6	1.04	0	KD
3	1.37	0.10	1.04	1.30	0.11	52	7.2	0.7	1.10	0	KD
4	1.36	0.08	0.92	1.30	0.11	53	7.3	0.8	1.00	0	RC
5	1.32	0.09	0.98	1.21	0.12	52	7.3	0.8	0.91	0	RC
6	1.39	0.07	0.90	1.15	0.12	52	7.2	0.7	1.03	0	KD
7	1.37	0.08	0.94	1.33	0.10	50	7.3	0.7	1.00	0	KD
8	1.36	0.08	0.94	1.26	0.11	51	7.2	0.7	0.98	0	RC
9	1.48	0.08	1.08	1.25	0.10	51	7.2	0.8	0.96	0	RC
10	1.26	0.08	1.15	1.31	0.09	50	7.3	0.7	1.09	0	RC
11	1.48	0.04	1.25	1.25	0.10	50	7.2	0.8	1.11	0	RC
12	1.32	0.09	1.38	1.10	0.12	51	7.3	0.8	1.22	0	RC
13	1.33	0.07	1.41	1.38	0.12	50	7.3	0.8	1.27	0	RC
14	1.29	0.08	1.19	1.22	0.11	49	7.3	0.8	1.29	0	RC
15	1.36	0.09	1.26	1.30	0.10	47	7.3	0.8	1.16	0	AM
16	1.39	0.09	1.29	1.30	0.10	48	7.2	0.8	1.21	0	AM
17	1.31	0.10	1.28	1.28	0.11	48	7.1	0.8	1.19	0	AM
18	1.35	0.08	1.33	1.38	0.12	50	7.1	0.7	1.23	0	JS
19	1.28	0.09	1.36	1.13	0.14	49	7.1	0.8	1.28	0	AM
20	1.33	0.08	1.27	1.11	0.11	49	7.0	0.8	1.19	0	AM
21	1.36	0.10	1.29	1.13	0.11	48	7.0	0.8	1.26	0	AM
22	1.39	0.08	1.30	1.40	0.10	50	7.0	0.8	1.35	0	JS
23	1.35	0.07	1.35	1.48	0.09	49	7.0	0.8	1.35	0	JS
24	1.37	0.06	1.65	1.39	0.09	50	7.1	0.8	1.66	0	JS
25	1.45	0.08	1.41	1.41	0.08	49	7.1	0.8	1.29	0	AM
26	1.40	0.07	1.36	1.40	0.09	48	7.1	0.8	1.27	0	AM
27	1.36	0.06	1.36	1.41	0.11	50	7.0	0.7	1.17	0	JS
28	1.35	0.07	1.37	1.42	0.10	50	7.0	0.8	1.26	0	JS
29	1.40	0.07	1.30	1.39	0.11	52	7.0	0.7	1.34	0	JS
30	1.37	0.08	1.28	1.40	0.10	50	7.1	0.8	1.27	0	AM
31	1.36	0.08	1.37	1.30	0.09	49	7.1	0.9	1.33	0	AM
AVG.	1.36	0.08	1.22	1.30	0.11	50	7.2	0.8	1.18	0	
MAX.	1.48	0.10	1.65	1.48	0.14	53	7.3	0.9	1.66	0	
MIN.	1.26	0.04	0.90	1.10	0.08	47	7.0	0.6	0.91	0	

 2/5/25
 Mike Weed, Operations Supervisor
 Illinois ROINC # 186860234


DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
FEBRUARY 2025

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.33	0.09	1.29	1.44	0.09	50	7.1	0.8	1.34	0	JS
2	1.31	0.10	1.31	1.39	0.09	49	7.1	0.8	1.37	0	JS
3	1.35	0.08	1.27	1.28	0.09	50	7.0	0.7	1.29	0	AM
4	1.32	0.07	1.42	1.27	0.10	48	7.1	0.7	1.38	0	JS
5	1.43	0.09	1.45	1.40	0.09	47	7.0	0.8	1.24	0	JS
6	1.38	0.06	1.28	1.37	0.09	48	7.1	0.7	1.44	0	JS
7	1.41	0.06	1.40	1.40	0.10	47	7.0	0.7	1.32	0	JS
8	1.39	0.07	1.41	1.38	0.09	47	7.0	0.8	1.35	0	KD
9	1.46	0.08	1.21	1.20	0.14	49	7.0	0.8	1.35	0	KD
10	1.42	0.07	1.26	1.43	0.09	48	7.0	0.6	1.31	0	JS
11	1.41	0.08	1.54	1.29	0.09	49	7.0	0.6	1.37	0	JS
12	1.52	0.05	1.31	1.25	0.90	47	7.0	0.6	1.49	0	KD
13	1.49	0.07	1.35	1.12	0.52	48	7.1	0.6	1.31	0	KD
14	1.41	0.06	1.35	1.41	0.14	41	7.0	0.7	1.36	0	KD
15	1.43	0.05	1.31	1.35	0.09	40	7.2	0.6	1.22	0	RC
16	1.44	0.05	1.56	1.09	0.16	47	7.2	0.6	1.31	0	RC
17	1.39	0.05	1.56	1.09	0.14	45	7.2	0.5	1.53	0	KD
18	1.36	0.05	1.43	1.05	0.14	45	7.1	0.6	1.49	0	KD
19	1.42	0.05	1.46	1.23	0.11	44	7.1	0.6	1.60	0	RC
20	1.42	0.05	1.47	1.38	0.07	42	7.1	0.6	1.46	0	RC
21	1.38	0.06	1.49	1.22	0.10	47	7.1	0.5	1.52	0	RC
22	1.43	0.06	1.57	1.28	0.08	46	7.1	0.5	1.52	0	KD
23	1.42	0.06	1.35	1.10	0.12	49	7.0	0.5	1.48	0	KD
24	1.27	0.06	1.43	1.30	0.12	50	7.1	0.6	1.48	0	RC
25	1.26	0.07	1.46	1.21	0.07	41	7.1	0.6	1.36	0	RC
26	1.27	0.07	1.33	1.07	0.10	47	7.1	0.5	1.40	0	KD
27	1.41	0.08	1.50	1.19	0.08	50	7.0	0.5	1.35	0	KD
28	1.37	0.05	1.36	1.18	0.11	47	7.0	0.6	1.48	0	KD
29											
30											
31											
AVG.	1.39	0.07	1.40	1.26	0.15	47	7.1	0.6	1.40	0	
MAX.	1.52	0.10	1.57	1.44	0.90	50	7.2	0.8	1.60	0	
MIN.	1.26	0.05	1.21	1.05	0.07	40	7.0	0.5	1.22	0	

 3/5/25
 Mike Weed, Operations Supervisor Date
 Illinois ROINC # 186860234

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
MARCH 2025

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.42	0.05	1.43	1.23	0.12	49	7.1	0.5	1.42	0	RC
2	1.44	0.06	1.62	1.19	0.09	44	7.1	0.6	1.34	0	RC
3	1.32	0.05	1.37	0.95	0.12	51	7.1	0.6	1.46	0	KD
4	1.43	0.06	1.47	1.24	0.08	43	7.1	0.6	1.56	0	KD
5	1.33	0.06	1.46	1.21	0.08	45	7.0	0.9	1.34	0	RC
6	1.46	0.06	1.44	1.20	0.08	46	7.1	0.8	1.17	0	RC
7	1.39	0.07	1.64	1.16	0.12	46	7.1	0.7	1.51	0	RC
8	1.36	0.06	1.56	1.23	0.10	44	7.0	0.7	1.41	0	AM
9	1.41	0.09	1.39	1.19	0.11	46	7.0	0.7	1.19	0	AM
10	1.43	0.05	1.53	1.27	0.08	46	7.0	0.7	1.48	0	RC
11	1.35	0.06	1.55	1.24	0.08	45	7.1	0.7	1.56	0	RC
12	1.33	0.07	1.69	1.20	0.09	47	7.0	0.7	1.47	0	AM
13	1.38	0.07	1.51	1.18	0.10	47	7.0	0.7	1.36	0	AM
14	1.37	0.07	1.59	1.21	0.10	48	7.0	0.8	1.55	0	AM
15	1.36	0.07	1.56	1.26	0.09	49	7.0	0.8	1.57	0	JS
16	1.42	0.05	1.63	1.21	0.07	50	7.1	0.6	1.58	0	JS
17	1.35	0.08	1.71	1.20	0.10	48	7.1	0.8	1.71	0	AM
18	1.41	0.07	1.73	1.17	0.10	49	7.1	0.9	1.65	0	AM
19	1.36	0.05	1.76	1.22	0.10	50	7.0	0.8	1.70	0	JS
20	1.44	0.05	1.74	1.30	0.10	51	7.1	0.8	1.73	0	JS
21	1.37	0.08	1.62	1.19	0.07	51	7.1	0.6	1.76	0	JS
22	1.33	0.07	1.79	1.21	0.08	50	7.1	0.9	1.70	0	AM
23	1.37	0.06	1.74	1.18	0.09	51	7.0	0.9	1.77	0	AM
24	1.41	0.05	1.69	1.22	0.07	51	7.1	0.8	1.76	0	JS
25	1.38	0.08	1.70	1.25	0.08	52	7.1	0.8	1.59	0	JS
26	1.36	0.08	1.73	1.18	0.09	52	7.1	0.8	1.60	0	AM
27	1.38	0.06	1.60	1.19	0.09	52	7.0	0.8	1.71	0	AM
28	1.42	0.06	1.69	1.21	0.10	53	7.1	0.8	1.74	0	AM
29	1.42	0.05	1.60	1.27	0.08	53	7.1	0.7	1.59	0	JS
30	1.50	0.05	1.49	1.35	0.09	54	7.1	0.8	1.58	0	JS
31	1.47	0.05	1.58	1.14	0.07	54	7.1	0.8	1.51	0	JS
AVG.	1.39	0.06	1.60	1.21	0.09	49	7.1	0.7	1.55	0	
MAX.	1.50	0.09	1.79	1.35	0.12	54	7.1	0.9	1.77	0	
MIN.	1.32	0.05	1.37	0.95	0.07	43	7.0	0.5	1.17	0	


Mike Weed, Operations Supervisor
Illinois ROINC # 186860234

4/3/25
Date

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
APRIL 2025


DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.44	0.06	1.13	1.09	0.08	52	7.1	0.9	1.28	0	RC
2	1.30	0.04	0.93	1.01	0.08	54	7.1	0.8	1.33	0	JS
3	1.30	0.06	1.38	1.03	0.09	54	7.1	0.8	1.22	0	KD
4	1.19	0.05	1.41	1.06	0.07	52	7.1	0.8	1.48	0	KD
5	1.40	0.04	1.58	1.13	0.07	50	7.1	0.8	1.51	0	KD
6	1.31	0.07	1.66	1.06	0.08	54	7.1	0.8	1.65	0	KD
7	1.41	0.06	1.44	1.12	0.08	55	7.1	0.7	1.60	0	JS
8	1.33	0.05	1.61	1.03	0.07	55	7.1	0.8	1.58	0	JS
9	1.35	0.04	2.08	1.24	0.07	48	7.0	0.8	1.47	0	KD
10	1.22	0.05	1.76	1.19	0.07	51	7.0	0.8	1.78	0	KD
11	1.36	0.05	2.13	1.13	0.07	49	7.0	0.8	1.96	0	KD
12	1.40	0.05	2.11	1.20	0.07	49	7.1	0.9	2.37	0	RC
13	1.44	0.06	2.07	1.24	0.08	50	7.0	0.9	2.11	0	RC
14	1.32	0.06	2.15	1.16	0.07	50	7.0	0.7	2.13	0	KD
15	1.28	0.06	2.35	1.10	0.08	50	7.0	0.8	2.21	0	KD
16	1.32	0.06	2.23	1.12	0.08	49	7.0	0.8	2.36	0	KD
17	1.29	0.06	2.19	1.31	0.07	50	7.0	0.9	2.19	0	RC
18	1.26	0.06	2.15	1.26	0.07	51	7.1	0.9	2.11	0	RC
19	1.29	0.05	2.07	1.17	0.07	50	7.0	0.8	2.16	0	KD
20	1.24	0.06	2.11	1.14	0.06	51	7.0	0.8	2.12	0	KD
21	1.31	0.05	2.12	1.32	0.07	52	7.1	0.9	2.08	0	RC
22	1.23	0.05	2.18	1.24	0.07	52	7.1	0.8	2.06	0	RC
23	1.32	0.06	2.12	1.36	0.06	52	7.1	0.8	2.35	0	KD
24	1.27	0.05	2.19	1.18	0.06	52	7.0	0.8	2.17	0	KD
25	1.31	0.05	2.19	1.12	0.06	52	7.0	0.8	2.24	0	KD
26	1.49	0.05	2.14	1.40	0.06	53	7.1	0.9	2.10	0	RC
27	1.42	0.04	2.00	1.29	0.06	53	7.1	0.8	2.02	0	AM
28	1.37	0.06	2.19	1.16	0.07	53	7.0	0.8	2.22	0	KD
29	1.31	0.05	2.19	1.21	0.06	54	7.0	0.8	2.28	0	KD
30	1.25	0.05	2.10	1.10	0.06	54	7.0	0.8	2.15	0	KD
31											
AVG.	1.32	0.05	1.93	1.17	0.07	52	7.1	0.8	1.94	0	
MAX.	1.49	0.07	2.35	1.40	0.09	55	7.1	0.9	2.37	0	
MIN.	1.19	0.04	0.93	1.01	0.06	48	7.0	0.7	1.22	0	


Mike Weed, Operations Supervisor
Illinois ROINC # 186860234

5-5-25
Date

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
MAY 2025


DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.44	0.05	1.99	1.20	0.07	55	7.0	0.8	2.26	0	KD
2	1.38	0.07	2.05	1.24	0.08	56	7.1	0.8	2.01	0	AM
3	1.39	0.05	2.16	1.27	0.08	56	7.1	0.8	2.03	0	AM
4	1.36	0.06	2.03	1.33	0.08	56	7.0	0.7	2.18	0	AM
5	1.31	0.06	2.16	1.31	0.08	55	7.1	0.7	2.17	0	RC
6	1.35	0.06	2.15	1.35	0.06	55	7.1	0.7	2.12	0	RC
7	1.38	0.06	2.08	1.28	0.06	55	7.2	0.8	2.19	0	AM
8	1.36	0.06	2.01	1.29	0.07	55	7.2	0.8	2.13	0	AM
9	1.37	0.07	2.19	1.33	0.06	56	7.1	0.7	2.16	0	AM
10	1.33	0.05	2.12	1.23	0.06	56	7.1	0.8	2.08	0	JS
11	1.38	0.05	2.11	1.40	0.06	56	7.1	0.8	2.07	0	JS
12	1.36	0.05	2.19	1.31	0.07	56	7.2	0.8	2.13	0	AM
13	1.38	0.06	2.11	1.09	0.08	57	7.2	0.7	2.26	0	AM
14	1.37	0.06	1.83	1.26	0.07	58	7.1	0.7	1.98	0	JS
15	1.34	0.05	2.17	1.29	0.07	59	7.1	0.7	1.87	0	JS
16	1.22	0.06	2.00	1.17	0.07	60	7.2	0.6	2.04	0	JS
17	1.36	0.05	2.35	1.13	0.08	60	7.1	0.6	2.24	0	JS
18	1.32	0.06	2.28	1.14	0.08	60	7.1	0.7	2.29	0	AM
19	1.37	0.06	2.26	1.16	0.06	59	7.0	0.6	2.35	0	JS
20	1.39	0.06	2.32	1.26	0.06	59	7.1	0.6	2.26	0	JS
21	1.33	0.08	2.26	1.24	0.05	60	7.1	0.6	2.30	0	AM
22	1.35	0.08	2.31	1.19	0.05	60	7.1	0.7	2.25	0	AM
23	1.38	0.07	2.22	1.16	0.07	59	7.0	0.7	2.30	0	AM
24	1.42	0.06	2.30	1.17	0.07	60	7.1	0.7	2.24	0	JS
25	1.48	0.06	2.25	1.32	0.08	60	7.1	0.6	2.27	0	JS
26	1.44	0.07	2.29	1.27	0.07	60	7.1	0.6	2.29	0	AM
27	1.38	0.04	2.25	1.17	0.08	59	7.1	0.6	2.22	0	AM
28	1.37	0.06	2.35	1.25	0.06	58	7.1	0.6	2.27	0	JS
29	1.31	0.06	2.30	1.25	0.07	58	7.1	0.5	2.35	0	JS
30	1.36	0.06	2.31	1.29	0.07	58	7.2	0.6	2.33	0	JS
31	1.39	0.07	2.27	1.29	0.07	59	7.1	0.7	2.24	0	KD
AVG.	1.37	0.06	2.18	1.25	0.07	58	7.1	0.7	2.19	0	
MAX.	1.48	0.08	2.35	1.40	0.08	60	7.2	0.8	2.35	0	
MIN.	1.22	0.04	1.83	1.09	0.05	55	7.0	0.5	1.87	0	


Mike Weed, Operations Supervisor
Illinois ROINC # 186860234

6/3/25
Date

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
JUNE 2025

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.38	0.06	2.26	1.32	0.08	59	7.1	0.6	2.27	0	KD
2	1.33	0.05	2.25	1.33	0.06	60	7.0	0.6	2.24	0	JS
3	1.36	0.05	2.30	1.29	0.06	60	7.1	0.6	2.28	0	JS
4	1.38	0.05	2.29	1.26	0.08	59	7.1	0.7	2.31	0	KD
5	1.31	0.05	2.24	1.22	0.06	60	7.1	0.6	2.24	0	KD
6	1.33	0.05	2.24	1.19	0.07	60	7.1	0.6	2.51	0	KD
7	1.34	0.06	2.27	1.20	0.07	59	7.1	0.6	2.28	0	JS
8	1.38	0.05	2.26	1.26	0.06	59	7.1	0.6	2.26	0	RC
9	1.31	0.05	2.24	1.26	0.06	58	7.1	0.7	2.23	0	RC
10	1.31	0.05	2.24	1.29	0.06	60	7.1	0.7	2.28	0	KD
11	1.37	0.04	2.30	1.34	0.05	60	7.1	0.6	2.20	0	RC
12	1.41	0.05	2.35	1.33	0.05	61	7.1	0.6	2.34	0	RC
13	1.37	0.05	2.35	1.29	0.06	61	7.1	0.6	2.33	0	RC
14	1.39	0.06	2.36	1.27	0.07	62	7.1	0.6	2.50	0	KD
15	1.34	0.05	2.28	1.32	0.06	62	7.1	0.6	2.26	0	KD
16	1.15	0.05	2.24	1.17	0.06	63	7.1	0.6	2.31	0	KD
17	1.21	0.05	2.20	1.28	0.06	63	7.1	0.7	2.27	0	AM
18	1.30	0.06	2.17	1.24	0.07	63	7.0	0.6	2.37	0	KD
19	1.31	0.05	2.19	1.13	0.08	63	7.1	0.6	2.31	0	KD
20	1.24	0.06	2.27	1.13	0.07	63	7.1	0.6	2.49	0	KD
21	1.36	0.09	2.29	1.26	0.07	64	7.2	0.6	2.27	0	RC
22	1.28	0.08	2.21	1.17	0.09	64	7.2	0.7	2.25	0	RC
23	1.33	0.09	2.24	1.24	0.08	65	7.1	0.6	2.24	0	KD
24	1.16	0.05	2.25	1.31	0.06	65	7.0	0.6	2.26	0	KD
25	1.35	0.06	2.21	1.33	0.05	65	7.0	0.6	2.22	0	RC
26	1.47	0.06	2.21	1.38	0.06	64	7.1	0.6	2.17	0	RC
27	1.22	0.06	2.11	1.26	0.08	64	7.2	0.6	2.22	0	RC
28	1.29	0.06	2.29	1.28	0.09	65	7.1	0.7	2.30	0	AM
29	1.26	0.05	2.21	1.31	0.08	65	7.1	0.6	2.23	0	AM
30	1.36	0.06	2.27	1.27	0.06	65	7.1	0.7	2.36	0	RC
31											
AVG.	1.32	0.06	2.25	1.26	0.07	62	7.1	0.6	2.29	0	
MAX.	1.47	0.09	2.36	1.38	0.09	65	7.2	0.7	2.51	0	
MIN.	1.15	0.04	2.11	1.13	0.05	58	7.0	0.6	2.17	0	


Mike Weed, Operations Supervisor
Illinois ROINC # 186860234

7/7/25
Date