

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
JANUARY 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.41                  | 0.06            | 0.59         | 1.38                  | 0.07            | 48        | 7.7 | 0.8             | 0.52         | 0               | RC           |
| 2    | 1.25                  | 0.07            | 0.58         | 1.30                  | 0.08            | 51        | 7.7 | 0.7             | 0.49         | 0               | CT           |
| 3    | 1.35                  | 0.08            | 0.63         | 1.34                  | 0.07            | 50        | 7.7 | 0.7             | 0.61         | 0               | CT           |
| 4    | 1.38                  | 0.06            | 0.61         | 1.35                  | 0.06            | 49        | 7.5 | 0.8             | 0.53         | 0               | RC           |
| 5    | 1.22                  | 0.06            | 0.60         | 1.24                  | 0.07            | 48        | 7.7 | 0.8             | 0.52         | 0               | RC           |
| 6    | 1.31                  | 0.09            | 0.61         | 1.26                  | 0.09            | 50        | 7.5 | 0.7             | 0.55         | 0               | CT           |
| 7    | 1.33                  | 0.08            | 0.65         | 1.24                  | 0.09            | 48        | 7.6 | 0.7             | 0.58         | 0               | CT           |
| 8    | 1.37                  | 0.07            | 0.69         | 1.30                  | 0.09            | 49        | 7.5 | 0.8             | 0.53         | 0               | CT           |
| 9    | 1.25                  | 0.09            | 0.61         | 1.27                  | 0.09            | 48        | 7.7 | 0.7             | 0.54         | 0               | CT           |
| 10   | 1.39                  | 0.08            | 0.63         | 1.39                  | 0.09            | 48        | 7.8 | 0.8             | 0.57         | 0               | AM           |
| 11   | 1.37                  | 0.07            | 0.68         | 1.32                  | 0.08            | 49        | 7.7 | 0.8             | 0.61         | 0               | CT           |
| 12   | 1.41                  | 0.08            | 0.58         | 1.29                  | 0.09            | 48        | 7.6 | 0.8             | 0.56         | 0               | CT           |
| 13   | 1.44                  | 0.06            | 0.48         | 1.41                  | 0.07            | 46        | 7.8 | 0.8             | 0.52         | 0               | RC           |
| 14   | 1.34                  | 0.06            | 0.57         | 1.34                  | 0.06            | 46        | 7.7 | 0.8             | 0.48         | 0               | RC           |
| 15   | 1.33                  | 0.06            | 0.60         | 1.32                  | 0.07            | 46        | 7.7 | 0.8             | 0.52         | 0               | RC           |
| 16   | 1.38                  | 0.07            | 0.58         | 1.33                  | 0.08            | 45        | 7.8 | 0.8             | 0.55         | 0               | AM           |
| 17   | 1.37                  | 0.08            | 0.61         | 1.38                  | 0.09            | 45        | 7.8 | 0.7             | 0.56         | 0               | AM           |
| 18   | 1.36                  | 0.06            | 0.67         | 1.34                  | 0.07            | 47        | 7.7 | 0.8             | 0.60         | 0               | RC           |
| 19   | 1.44                  | 0.07            | 0.75         | 1.35                  | 0.06            | 47        | 7.7 | 0.8             | 0.62         | 0               | RC           |
| 20   | 1.37                  | 0.08            | 0.69         | 1.36                  | 0.09            | 45        | 7.8 | 0.8             | 0.61         | 0               | AM           |
| 21   | 1.39                  | 0.09            | 0.64         | 1.33                  | 0.10            | 46        | 7.8 | 0.8             | 0.57         | 0               | AM           |
| 22   | 1.41                  | 0.09            | 0.56         | 1.37                  | 0.09            | 46        | 7.8 | 0.8             | 0.55         | 0               | AM           |
| 23   | 1.30                  | 0.09            | 0.64         | 1.38                  | 0.08            | 45        | 7.7 | 0.6             | 0.52         | 0               | KD           |
| 24   | 1.37                  | 0.07            | 0.66         | 1.33                  | 0.08            | 45        | 7.7 | 0.6             | 0.51         | 0               | KD           |
| 25   | 1.36                  | 0.08            | 0.58         | 1.35                  | 0.09            | 43        | 7.8 | 0.6             | 0.53         | 0               | AM           |
| 26   | 1.35                  | 0.09            | 0.60         | 1.34                  | 0.09            | 43        | 7.8 | 0.6             | 0.54         | 0               | AM           |
| 27   | 1.24                  | 0.09            | 0.60         | 1.26                  | 0.08            | 45        | 7.7 | 0.6             | 0.62         | 0               | KD           |
| 28   | 1.52                  | 0.08            | 0.67         | 1.37                  | 0.08            | 45        | 7.7 | 0.6             | 0.63         | 0               | KD           |
| 29   | 1.37                  | 0.06            | 0.59         | 1.36                  | 0.08            | 45        | 7.7 | 0.6             | 0.54         | 0               | KD           |
| 30   | 1.38                  | 0.08            | 0.60         | 1.35                  | 0.09            | 43        | 7.6 | 0.7             | 0.57         | 0               | AM           |
| 31   | 1.34                  | 0.09            | 0.58         | 1.38                  | 0.10            | 43        | 7.6 | 0.7             | 0.59         | 0               | AM           |
| AVG. | 1.36                  | 0.08            | 0.62         | 1.33                  | 0.08            | 47        | 7.7 | 0.7             | 0.56         | 0               |              |
| MAX. | 1.52                  | 0.09            | 0.75         | 1.41                  | 0.10            | 51        | 7.8 | 0.8             | 0.63         | 0               |              |
| MIN. | 1.22                  | 0.06            | 0.48         | 1.24                  | 0.06            | 43        | 7.5 | 0.6             | 0.48         | 0               |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

2/1/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
FEBRUARY 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.36                  | 0.09            | 0.66         | 1.28                  | 0.08            | 46        | 7.7 | 0.8             | 0.54         | 0               | KD           |
| 2    | 1.37                  | 0.07            | 0.53         | 1.28                  | 0.07            | 44        | 7.7 | 0.7             | 0.57         | 0               | KD           |
| 3    | 1.41                  | 0.08            | 0.57         | 1.37                  | 0.08            | 43        | 7.7 | 0.7             | 0.53         | 0               | AM           |
| 4    | 1.35                  | 0.09            | 0.55         | 1.30                  | 0.10            | 43        | 7.7 | 0.8             | 0.49         | 0               | AM           |
| 5    | 1.42                  | 0.10            | 0.57         | 1.38                  | 0.11            | 43        | 7.7 | 0.7             | 0.58         | 0               | AM           |
| 6    | 1.41                  | 0.09            | 0.61         | 1.36                  | 0.09            | 44        | 7.6 | 0.8             | 0.58         | 0               | KD           |
| 7    | 1.33                  | 0.06            | 0.66         | 1.33                  | 0.09            | 43        | 7.7 | 0.8             | 0.61         | 0               | KD           |
| 8    | 1.35                  | 0.06            | 0.51         | 1.36                  | 0.08            | 43        | 7.6 | 0.7             | 0.52         | 0               | AM           |
| 9    | 1.38                  | 0.07            | 0.53         | 1.37                  | 0.09            | 43        | 7.6 | 0.7             | 0.52         | 0               | AM           |
| 10   | 1.45                  | 0.07            | 0.52         | 1.30                  | 0.06            | 43        | 7.6 | 0.8             | 0.52         | 0               | KD           |
| 11   | 1.55                  | 0.07            | 0.57         | 1.28                  | 0.06            | 43        | 7.7 | 0.7             | 0.54         | 0               | KD           |
| 12   | 1.54                  | 0.08            | 0.64         | 1.43                  | 0.08            | 44        | 7.3 | 0.7             | 0.64         | 0               | KD           |
| 13   | 1.42                  | 0.07            | 0.62         | 1.34                  | 0.07            | 47        | 7.6 | 0.9             | 0.53         | 0               | CT           |
| 14   | 1.40                  | 0.08            | 0.66         | 1.33                  | 0.07            | 48        | 7.5 | 0.8             | 0.49         | 0               | CT           |
| 15   | 1.50                  | 0.07            | 0.53         | 1.41                  | 0.07            | 45        | 7.5 | 0.7             | 0.62         | 0               | KD           |
| 16   | 1.38                  | 0.08            | 0.49         | 1.36                  | 0.09            | 43        | 7.6 | 0.7             | 0.53         | 0               | AM           |
| 17   | 1.30                  | 0.07            | 0.56         | 1.35                  | 0.08            | 47        | 7.7 | 0.8             | 0.56         | 0               | CT           |
| 18   | 1.35                  | 0.08            | 0.58         | 1.39                  | 0.08            | 47        | 7.7 | 0.8             | 0.51         | 0               | CT           |
| 19   | 1.46                  | 0.06            | 0.72         | 1.32                  | 0.08            | 45        | 7.6 | 0.8             | 0.57         | 0               | CT           |
| 20   | 1.33                  | 0.06            | 0.44         | 1.39                  | 0.07            | 42        | 7.5 | 0.8             | 0.52         | 0               | RC           |
| 21   | 1.58                  | 0.06            | 0.66         | 1.29                  | 0.06            | 45        | 7.5 | 0.8             | 0.66         | 0               | RC           |
| 22   | 1.42                  | 0.07            | 0.61         | 1.33                  | 0.07            | 46        | 7.7 | 0.8             | 0.43         | 0               | CT           |
| 23   | 1.38                  | 0.07            | 0.47         | 1.26                  | 0.07            | 48        | 7.7 | 0.8             | 0.48         | 0               | CT           |
| 24   | 1.33                  | 0.07            | 0.60         | 1.34                  | 0.08            | 47        | 7.6 | 0.9             | 0.55         | 0               | RC           |
| 25   | 1.36                  | 0.08            | 0.57         | 1.32                  | 0.08            | 46        | 7.6 | 0.8             | 0.54         | 0               | AM           |
| 26   | 1.42                  | 0.05            | 0.62         | 1.25                  | 0.07            | 44        | 7.6 | 0.7             | 0.63         | 0               | RC           |
| 27   | 1.46                  | 0.06            | 0.67         | 1.37                  | 0.06            | 46        | 7.6 | 0.8             | 0.60         | 0               | RC           |
| 28   | 1.45                  | 0.06            | 0.65         | 1.39                  | 0.06            | 45        | 7.6 | 0.8             | 0.61         | 0               | RC           |
| AVG. | 1.41                  | 0.07            | 0.58         | 1.34                  | 0.08            | 45        | 7.6 | 0.8             | 0.55         | 0               |              |
| MAX. | 1.58                  | 0.10            | 0.72         | 1.43                  | 0.11            | 48        | 7.7 | 0.9             | 0.66         | 0               |              |
| MIN. | 1.30                  | 0.05            | 0.44         | 1.25                  | 0.06            | 42        | 7.3 | 0.7             | 0.43         | 0               |              |

  
 Alan E. Stark, Coordinating Engineer  
 Illinois ROINC # 84789479

3/2/2021  
 Date

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
MARCH 2021

| DATE | LEXINGTON P.S. SUPPLY |                    |                 | DUPAGE P.S. DISCHARGE |                    |              |     |                    |                 |                    | ANALYST INT. |
|------|-----------------------|--------------------|-----------------|-----------------------|--------------------|--------------|-----|--------------------|-----------------|--------------------|--------------|
|      | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | O-PO4<br>(mg/L) | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | TEMP<br>(°F) | pH  | Fluoride<br>(mg/L) | O-PO4<br>(mg/L) | P.A.C.<br>(LBS/MG) |              |
| 1    | 1.38                  | 0.07               | 0.62            | 1.26                  | 0.07               | 47           | 7.6 | 0.7                | 0.63            | 0                  | RC           |
| 2    | 1.35                  | 0.06               | 0.65            | 1.28                  | 0.06               | 48           | 7.6 | 0.7                | 0.53            | 0                  | RC           |
| 3    | 1.29                  | 0.07               | 0.56            | 1.23                  | 0.07               | 50           | 7.6 | 0.6                | 0.62            | 0                  | CT           |
| 4    | 1.33                  | 0.06               | 0.62            | 1.21                  | 0.05               | 46           | 7.6 | 0.7                | 0.53            | 0                  | CT           |
| 5    | 1.33                  | 0.05               | 0.53            | 1.30                  | 0.08               | 49           | 7.6 | 0.8                | 0.57            | 0                  | CT           |
| 6    | 1.33                  | 0.06               | 0.53            | 1.25                  | 0.06               | 47           | 7.6 | 0.8                | 0.61            | 0                  | CT           |
| 7    | 1.39                  | 0.06               | 0.66            | 1.40                  | 0.06               | 45           | 7.6 | 0.8                | 0.54            | 0                  | RC           |
| 8    | 1.21                  | 0.07               | 0.48            | 1.34                  | 0.06               | 48           | 7.6 | 0.8                | 0.67            | 0                  | CT           |
| 9    | 1.47                  | 0.06               | 0.56            | 1.37                  | 0.06               | 48           | 7.6 | 0.8                | 0.54            | 0                  | CT           |
| 10   | 1.43                  | 0.06               | 0.55            | 1.48                  | 0.06               | 48           | 7.6 | 0.8                | 0.62            | 0                  | RC           |
| 11   | 1.45                  | 0.06               | 0.71            | 1.42                  | 0.06               | 50           | 7.6 | 0.8                | 0.71            | 0                  | CT           |
| 12   | 1.35                  | 0.08               | 0.51            | 1.29                  | 0.06               | 51           | 7.6 | 0.9                | 0.52            | 0                  | CT           |
| 13   | 1.38                  | 0.08               | 0.57            | 1.32                  | 0.06               | 50           | 7.6 | 0.8                | 0.56            | 0                  | AM           |
| 14   | 1.36                  | 0.07               | 0.58            | 1.30                  | 0.07               | 50           | 7.6 | 0.8                | 0.57            | 0                  | AM           |
| 15   | 1.39                  | 0.08               | 0.59            | 1.31                  | 0.07               | 50           | 7.6 | 0.7                | 0.54            | 0                  | AM           |
| 16   | 1.42                  | 0.07               | 0.57            | 1.32                  | 0.08               | 50           | 7.6 | 0.8                | 0.56            | 0                  | AM           |
| 17   | 1.38                  | 0.08               | 0.56            | 1.33                  | 0.08               | 49           | 7.6 | 0.8                | 0.53            | 0                  | AM           |
| 18   | 1.42                  | 0.06               | 0.54            | 1.37                  | 0.08               | 50           | 7.6 | 0.7                | 0.50            | 0                  | AM           |
| 19   | 1.40                  | 0.07               | 0.58            | 1.38                  | 0.08               | 49           | 7.6 | 0.7                | 0.51            | 0                  | AM           |
| 20   | 1.29                  | 0.06               | 0.61            | 1.25                  | 0.08               | 52           | 7.5 | 0.8                | 0.57            | 0                  | KD           |
| 21   | 1.43                  | 0.07               | 0.60            | 1.27                  | 0.06               | 51           | 7.5 | 0.7                | 0.59            | 0                  | KD           |
| 22   | 1.39                  | 0.07               | 0.59            | 1.29                  | 0.08               | 51           | 7.6 | 0.7                | 0.56            | 0                  | AM           |
| 23   | 1.40                  | 0.08               | 0.57            | 1.34                  | 0.09               | 50           | 7.6 | 0.8                | 0.53            | 0                  | AM           |
| 24   | 1.30                  | 0.06               | 0.60            | 1.25                  | 0.07               | 52           | 7.5 | 0.8                | 0.61            | 0                  | KD           |
| 25   | 1.28                  | 0.06               | 0.63            | 1.28                  | 0.07               | 49           | 7.5 | 0.8                | 0.63            | 0                  | KD           |
| 26   | 1.42                  | 0.06               | 0.61            | 1.37                  | 0.08               | 49           | 7.5 | 0.8                | 0.57            | 0                  | KD           |
| 27   | 1.44                  | 0.07               | 0.62            | 1.39                  | 0.08               | 50           | 7.6 | 0.8                | 0.56            | 0                  | AM           |
| 28   | 1.45                  | 0.07               | 0.59            | 1.40                  | 0.08               | 50           | 7.6 | 0.8                | 0.54            | 0                  | AM           |
| 29   | 1.39                  | 0.05               | 0.64            | 1.36                  | 0.06               | 50           | 7.6 | 0.7                | 0.56            | 0                  | KD           |
| 30   | 1.30                  | 0.05               | 0.57            | 1.29                  | 0.06               | 51           | 7.5 | 0.7                | 0.54            | 0                  | KD           |
| 31   | 1.29                  | 0.07               | 0.58            | 1.30                  | 0.08               | 50           | 7.6 | 0.7                | 0.54            | 0                  | AM           |
| AVG. | 1.37                  | 0.07               | 0.59            | 1.32                  | 0.07               | 49           | 7.6 | 0.8                | 0.57            | 0                  |              |
| MAX. | 1.47                  | 0.08               | 0.71            | 1.48                  | 0.09               | 52           | 7.6 | 0.9                | 0.71            | 0                  |              |
| MIN. | 1.21                  | 0.05               | 0.48            | 1.21                  | 0.05               | 45           | 7.5 | 0.6                | 0.50            | 0                  |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

4/2/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
APRIL 2021

| DATE | LEXINGTON P.S. SUPPLY |                    |                 | DUPAGE P.S. DISCHARGE |                    |              |     |                    |                 |                    | ANALYST<br>INT. |
|------|-----------------------|--------------------|-----------------|-----------------------|--------------------|--------------|-----|--------------------|-----------------|--------------------|-----------------|
|      | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | O-PO4<br>(mg/L) | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | TEMP<br>(°F) | pH  | Fluoride<br>(mg/L) | O-PO4<br>(mg/L) | P.A.C.<br>(LBS/MG) |                 |
| 1    | 1.28                  | 0.08               | 0.57            | 1.31                  | 0.09               | 50           | 7.6 | 0.8                | 0.56            | 0                  | AM              |
| 2    | 1.24                  | 0.07               | 0.61            | 1.28                  | 0.09               | 49           | 7.6 | 0.8                | 0.57            | 0                  | AM              |
| 3    | 1.25                  | 0.07               | 0.63            | 1.22                  | 0.07               | 50           | 7.6 | 0.7                | 0.57            | 0                  | KD              |
| 4    | 1.34                  | 0.05               | 0.66            | 1.29                  | 0.08               | 50           | 7.5 | 0.7                | 0.69            | 0                  | KD              |
| 5    | 1.36                  | 0.07               | 0.61            | 1.31                  | 0.08               | 51           | 7.6 | 0.8                | 0.59            | 0                  | AM              |
| 6    | 1.30                  | 0.06               | 0.56            | 1.26                  | 0.09               | 50           | 7.6 | 0.7                | 0.53            | 0                  | AM              |
| 7    | 1.37                  | 0.07               | 0.57            | 1.32                  | 0.10               | 50           | 7.5 | 0.8                | 0.52            | 0                  | AM              |
| 8    | 1.32                  | 0.05               | 0.64            | 1.33                  | 0.09               | 52           | 7.7 | 0.7                | 0.52            | 0                  | CT              |
| 9    | 1.29                  | 0.07               | 0.53            | 1.28                  | 0.08               | 52           | 7.6 | 0.7                | 0.50            | 0                  | CT              |
| 10   | 1.36                  | 0.05               | 0.61            | 1.26                  | 0.06               | 53           | 7.6 | 0.8                | 0.55            | 0                  | CT              |
| 11   | 1.28                  | 0.06               | 0.57            | 1.28                  | 0.06               | 53           | 7.6 | 0.9                | 0.56            | 0                  | CT              |
| 12   | 1.29                  | 0.06               | 0.70            | 1.22                  | 0.06               | 54           | 7.6 | 0.8                | 0.52            | 0                  | CT              |
| 13   | 1.30                  | 0.06               | 0.56            | 1.28                  | 0.07               | 54           | 7.6 | 0.7                | 0.54            | 0                  | AM              |
| 14   | 1.22                  | 0.07               | 0.53            | 1.23                  | 0.06               | 54           | 7.7 | 0.8                | 0.49            | 0                  | CT              |
| 15   | 1.30                  | 0.06               | 0.59            | 1.25                  | 0.06               | 54           | 7.6 | 0.8                | 0.45            | 0                  | CT              |
| 16   | 1.28                  | 0.06               | 0.57            | 1.42                  | 0.06               | 55           | 7.6 | 0.8                | 0.47            | 0                  | CT              |
| 17   | 1.31                  | 0.05               | 0.57            | 1.50                  | 0.05               | 54           | 7.6 | 0.7                | 0.53            | 0                  | RC              |
| 18   | 1.42                  | 0.05               | 0.57            | 1.42                  | 0.06               | 56           | 7.5 | 0.9                | 0.59            | 0                  | RC              |
| 19   | 1.35                  | 0.05               | 0.58            | 1.22                  | 0.06               | 56           | 7.6 | 0.7                | 0.56            | 0                  | CT              |
| 20   | 1.34                  | 0.05               | 0.56            | 1.16                  | 0.07               | 57           | 7.6 | 1.0                | 0.49            | 0                  | CT              |
| 21   | 1.24                  | 0.06               | 0.56            | 1.27                  | 0.07               | 58           | 7.6 | 0.7                | 0.58            | 0                  | RC              |
| 22   | 1.28                  | 0.08               | 0.54            | 1.27                  | 0.08               | 56           | 7.6 | 0.7                | 0.55            | 0                  | RC              |
| 23   | 1.33                  | 0.07               | 0.57            | 1.24                  | 0.07               | 55           | 7.6 | 0.8                | 0.63            | 0                  | RC              |
| 24   | 1.35                  | 0.08               | 0.55            | 1.34                  | 0.08               | 55           | 7.6 | 0.8                | 0.57            | 0                  | RC              |
| 25   | 1.44                  | 0.07               | 0.60            | 1.34                  | 0.07               | 55           | 7.6 | 0.7                | 0.55            | 0                  | RC              |
| 26   | 1.31                  | 0.06               | 0.61            | 1.26                  | 0.07               | 56           | 7.6 | 0.7                | 0.58            | 0                  | RC              |
| 27   | 1.19                  | 0.07               | 0.51            | 1.18                  | 0.07               | 55           | 7.6 | 0.7                | 0.58            | 0                  | RC              |
| 28   | 1.28                  | 0.06               | 0.56            | 1.28                  | 0.06               | 56           | 7.6 | 0.6                | 0.79            | 0                  | CT              |
| 29   | 1.39                  | 0.06               | 0.57            | 1.20                  | 0.07               | 57           | 7.6 | 0.8                | 0.46            | 0                  | CT              |
| 30   | 1.22                  | 0.08               | 0.59            | 1.17                  | 0.06               | 57           | 7.6 | 0.7                | 0.50            | 0                  | CT              |
| AVG. | 1.31                  | 0.06               | 0.58            | 1.28                  | 0.07               | 54           | 7.6 | 0.8                | 0.55            | 0                  |                 |
| MAX. | 1.44                  | 0.08               | 0.70            | 1.50                  | 0.10               | 58           | 7.7 | 1.0                | 0.79            | 0                  |                 |
| MIN. | 1.19                  | 0.05               | 0.51            | 1.16                  | 0.05               | 49           | 7.5 | 0.6                | 0.45            | 0                  |                 |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

5/3/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
MAY 2021

| DATE | LEXINGTON P.S. SUPPLY |                    |                 | DUPAGE P.S. DISCHARGE |                    |              |     |                    |                 |                    | ANALYST<br>INT. |
|------|-----------------------|--------------------|-----------------|-----------------------|--------------------|--------------|-----|--------------------|-----------------|--------------------|-----------------|
|      | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | O-PO4<br>(mg/L) | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | TEMP<br>(°F) | pH  | Fluoride<br>(mg/L) | O-PO4<br>(mg/L) | P.A.C.<br>(LBS/MG) |                 |
| 1    | 1.26                  | 0.05               | 0.56            | 1.29                  | 0.06               | 56           | 7.5 | 0.8                | 0.52            | 0                  | RC              |
| 2    | 1.23                  | 0.05               | 0.64            | 1.31                  | 0.05               | 57           | 7.5 | 0.7                | 0.57            | 0                  | RC              |
| 3    | 1.28                  | 0.05               | 0.48            | 1.24                  | 0.07               | 57           | 7.6 | 0.9                | 0.48            | 0                  | CT              |
| 4    | 1.29                  | 0.07               | 0.60            | 1.22                  | 0.10               | 58           | 7.6 | 0.8                | 0.46            | 0                  | CT              |
| 5    | 1.30                  | 0.05               | 0.62            | 1.37                  | 0.05               | 58           | 7.5 | 0.8                | 0.53            | 0                  | RC              |
| 6    | 1.40                  | 0.05               | 0.68            | 1.26                  | 0.06               | 57           | 7.6 | 0.8                | 0.54            | 0                  | RC              |
| 7    | 1.16                  | 0.06               | 0.54            | 1.29                  | 0.06               | 58           | 7.5 | 0.7                | 0.54            | 0                  | RC              |
| 8    | 1.29                  | 0.07               | 0.57            | 1.30                  | 0.07               | 58           | 7.6 | 0.7                | 0.55            | 0                  | AM              |
| 9    | 1.33                  | 0.08               | 0.59            | 1.37                  | 0.08               | 58           | 7.6 | 0.6                | 0.57            | 0                  | AM              |
| 10   | 1.22                  | 0.05               | 0.57            | 1.32                  | 0.06               | 59           | 7.5 | 0.8                | 0.53            | 0                  | RC              |
| 11   | 1.09                  | 0.05               | 0.62            | 1.30                  | 0.06               | 58           | 7.5 | 0.8                | 0.52            | 0                  | RC              |
| 12   | 1.23                  | 0.06               | 0.59            | 1.35                  | 0.07               | 58           | 7.6 | 0.7                | 0.56            | 0                  | AM              |
| 13   | 1.28                  | 0.07               | 0.60            | 1.30                  | 0.07               | 58           | 7.6 | 0.8                | 0.57            | 0                  | AM              |
| 14   | 1.29                  | 0.07               | 0.58            | 1.29                  | 0.07               | 58           | 7.6 | 0.7                | 0.57            | 0                  | AM              |
| 15   | 1.28                  | 0.07               | 0.56            | 1.29                  | 0.07               | 60           | 7.6 | 0.9                | 0.54            | 0                  | CT              |
| 16   | 1.34                  | 0.06               | 0.58            | 1.31                  | 0.06               | 62           | 7.6 | 1.1                | 0.61            | 0                  | CT              |
| 17   | 1.32                  | 0.07               | 0.57            | 1.35                  | 0.08               | 61           | 7.6 | 0.9                | 0.57            | 0                  | AM              |
| 18   | 1.35                  | 0.07               | 0.56            | 1.33                  | 0.07               | 59           | 7.6 | 0.8                | 0.55            | 0                  | AM              |
| 19   | 1.28                  | 0.07               | 0.60            | 1.23                  | 0.08               | 56           | 7.6 | 0.7                | 0.63            | 0                  | KD              |
| 20   | 1.50                  | 0.07               | 0.55            | 1.35                  | 0.06               | 56           | 7.5 | 0.8                | 0.59            | 0                  | KD              |
| 21   | 1.40                  | 0.07               | 0.57            | 1.31                  | 0.07               | 56           | 7.6 | 0.6                | 0.55            | 0                  | KD              |
| 22   | 1.41                  | 0.08               | 0.55            | 1.37                  | 0.09               | 55           | 7.5 | 0.7                | 0.56            | 0                  | AM              |
| 23   | 1.39                  | 0.09               | 0.54            | 1.36                  | 0.09               | 55           | 7.5 | 0.7                | 0.56            | 0                  | AM              |
| 24   | 1.44                  | 0.06               | 0.61            | 1.37                  | 0.06               | 56           | 7.6 | 0.7                | 0.60            | 0                  | KD              |
| 25   | 1.42                  | 0.06               | 0.66            | 1.28                  | 0.07               | 60           | 7.5 | 0.7                | 0.60            | 0                  | KD              |
| 26   | 1.39                  | 0.06               | 0.59            | 1.30                  | 0.08               | 58           | 7.6 | 0.7                | 0.58            | 0                  | AM              |
| 27   | 1.31                  | 0.08               | 0.62            | 1.27                  | 0.08               | 57           | 7.7 | 0.9                | 0.60            | 0                  | AM              |
| 28   | 1.34                  | 0.09               | 0.60            | 1.30                  | 0.09               | 57           | 7.6 | 0.8                | 0.56            | 0                  | AM              |
| 29   | 1.42                  | 0.08               | 0.64            | 1.26                  | 0.08               | 58           | 7.5 | 0.8                | 0.62            | 0                  | KD              |
| 30   | 1.31                  | 0.07               | 0.61            | 1.26                  | 0.08               | 60           | 7.5 | 0.8                | 0.65            | 0                  | KD              |
| 31   | 1.37                  | 0.08               | 0.58            | 1.31                  | 0.09               | 59           | 7.6 | 0.8                | 0.57            | 0                  | AM              |
| AVG. | 1.32                  | 0.07               | 0.59            | 1.31                  | 0.07               | 58           | 7.6 | 0.8                | 0.56            | 0                  |                 |
| MAX. | 1.50                  | 0.09               | 0.68            | 1.37                  | 0.10               | 62           | 7.7 | 1.1                | 0.65            | 0                  |                 |
| MIN. | 1.09                  | 0.05               | 0.48            | 1.22                  | 0.05               | 55           | 7.5 | 0.6                | 0.46            | 0                  |                 |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

6/1/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
JUNE 2021

| DATE | LEXINGTON P.S. SUPPLY |                    |                 | DUPAGE P.S. DISCHARGE |                    |              |     |                    |                 |                    | ANALYST INT. |
|------|-----------------------|--------------------|-----------------|-----------------------|--------------------|--------------|-----|--------------------|-----------------|--------------------|--------------|
|      | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | O-PO4<br>(mg/L) | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | TEMP<br>(°F) | pH  | Fluoride<br>(mg/L) | O-PO4<br>(mg/L) | P.A.C.<br>(LBS/MG) |              |
| 1    | 1.45                  | 0.07               | 0.59            | 1.35                  | 0.09               | 59           | 7.6 | 0.8                | 0.54            | 0                  | AM           |
| 2    | 1.30                  | 0.06               | 0.56            | 1.33                  | 0.07               | 60           | 7.5 | 0.7                | 0.55            | 0                  | KD           |
| 3    | 1.46                  | 0.07               | 0.56            | 1.25                  | 0.09               | 60           | 7.4 | 0.7                | 0.60            | 0                  | KD           |
| 4    | 1.35                  | 0.06               | 0.54            | 1.31                  | 0.08               | 61           | 7.5 | 0.7                | 0.62            | 0                  | KD           |
| 5    | 1.45                  | 0.07               | 0.63            | 1.32                  | 0.09               | 63           | 7.4 | 0.7                | 0.64            | 0                  | KD           |
| 6    | 1.50                  | 0.08               | 0.52            | 1.35                  | 0.08               | 61           | 7.5 | 0.8                | 0.62            | 0                  | RC           |
| 7    | 1.54                  | 0.06               | 0.56            | 1.40                  | 0.06               | 63           | 7.6 | 0.7                | 0.52            | 0                  | CT           |
| 8    | 1.46                  | 0.07               | 0.57            | 1.37                  | 0.09               | 62           | 7.4 | 0.8                | 0.52            | 0                  | AM           |
| 9    | 1.24                  | 0.09               | 0.61            | 1.34                  | 0.06               | 63           | 7.7 | 0.8                | 0.52            | 0                  | CT           |
| 10   | 1.41                  | 0.07               | 0.53            | 1.34                  | 0.09               | 62           | 7.6 | 0.6                | 0.53            | 0                  | CT           |
| 11   | 1.50                  | 0.09               | 0.63            | 1.38                  | 0.07               | 63           | 7.6 | 0.8                | 0.66            | 0                  | CT           |
| 12   | 1.44                  | 0.05               | 0.56            | 1.26                  | 0.08               | 62           | 7.5 | 0.8                | 0.57            | 0                  | RC           |
| 13   | 1.45                  | 0.07               | 0.57            | 1.28                  | 0.10               | 63           | 7.5 | 0.8                | 0.60            | 0                  | RC           |
| 14   | 1.31                  | 0.08               | 0.80            | 1.19                  | 0.07               | 63           | 7.6 | 0.8                | 0.52            | 0                  | CT           |
| 15   | 1.29                  | 0.09               | 0.54            | 1.23                  | 0.07               | 62           | 7.6 | 0.7                | 0.52            | 0                  | CT           |
| 16   | 1.24                  | 0.06               | 0.61            | 1.33                  | 0.07               | 63           | 7.5 | 0.8                | 0.59            | 0                  | RC           |
| 17   | 1.40                  | 0.09               | 0.60            | 1.39                  | 0.10               | 65           | 7.4 | 0.8                | 0.65            | 0                  | RC           |
| 18   | 1.39                  | 0.07               | 0.61            | 1.37                  | 0.07               | 66           | 7.5 | 0.8                | 0.61            | 0                  | RC           |
| 19   | 1.24                  | 0.06               | 0.48            | 1.36                  | 0.08               | 67           | 7.5 | 0.8                | 0.56            | 0                  | CT           |
| 20   | 1.23                  | 0.08               | 0.50            | 1.20                  | 0.09               | 66           | 7.6 | 0.8                | 0.55            | 0                  | CT           |
| 21   | 1.43                  | 0.15               | 0.60            | 1.26                  | 0.15               | 65           | 7.5 | 0.7                | 0.53            | 0                  | RC           |
| 22   | 1.20                  | 0.11               | 0.58            | 1.15                  | 0.13               | 65           | 7.5 | 0.8                | 0.55            | 0                  | RC           |
| 23   | 1.31                  | 0.10               | 0.66            | 1.17                  | 0.12               | 66           | 7.6 | 0.7                | 0.58            | 0                  | CT           |
| 24   | 1.37                  | 0.11               | 0.63            | 1.32                  | 0.11               | 66           | 7.6 | 0.8                | 0.68            | 0                  | CT           |
| 25   | 1.16                  | 0.11               | 0.63            | 1.12                  | 0.14               | 66           | 7.6 | 0.8                | 0.60            | 0                  | CT           |
| 26   | 1.33                  | 0.10               | 0.65            | 1.18                  | 0.12               | 65           | 7.5 | 0.8                | 0.61            | 0                  | RC           |
| 27   | 1.35                  | 0.08               | 0.64            | 1.15                  | 0.09               | 65           | 7.5 | 0.8                | 0.64            | 0                  | RC           |
| 28   | 1.26                  | 0.07               | 0.58            | 1.33                  | 0.10               | 61           | 7.6 | 0.8                | 0.64            | 0                  | CT           |
| 29   | 1.41                  | 0.08               | 0.61            | 1.20                  | 0.11               | 62           | 7.6 | 0.8                | 0.56            | 0                  | CT           |
| 30   | 1.36                  | 0.08               | 0.62            | 1.27                  | 0.08               | 60           | 7.5 | 0.8                | 0.55            | 0                  | RC           |
| AVG. | 1.36                  | 0.08               | 0.59            | 1.28                  | 0.09               | 63           | 7.5 | 0.8                | 0.58            | 0                  |              |
| MAX. | 1.54                  | 0.15               | 0.80            | 1.40                  | 0.15               | 67           | 7.7 | 0.8                | 0.68            | 0                  |              |
| MIN. | 1.16                  | 0.05               | 0.48            | 1.12                  | 0.06               | 59           | 7.4 | 0.6                | 0.52            | 0                  |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

7/7/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
JULY 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.28                  | 0.06            | 0.63         | 1.27                  | 0.08            | 60        | 7.5 | 0.8             | 0.58         | 0               | RC           |
| 2    | 1.30                  | 0.07            | 0.61         | 1.15                  | 0.08            | 60        | 7.5 | 0.8             | 0.62         | 0               | RC           |
| 3    | 1.31                  | 0.06            | 0.62         | 1.29                  | 0.07            | 60        | 7.5 | 0.8             | 0.57         | 0               | RC           |
| 4    | 1.29                  | 0.07            | 0.62         | 1.25                  | 0.08            | 64        | 7.4 | 0.7             | 0.60         | 0               | AM           |
| 5    | 1.31                  | 0.07            | 0.60         | 1.21                  | 0.08            | 64        | 7.5 | 0.8             | 0.57         | 0               | AM           |
| 6    | 1.36                  | 0.10            | 0.52         | 1.26                  | 0.14            | 66        | 7.5 | 0.8             | 0.63         | 0               | CT           |
| 7    | 1.34                  | 0.10            | 0.59         | 1.22                  | 0.11            | 66        | 7.4 | 0.8             | 0.61         | 0               | AM           |
| 8    | 1.30                  | 0.09            | 0.55         | 1.14                  | 0.09            | 68        | 7.4 | 0.8             | 0.62         | 0               | KD           |
| 9    | 1.29                  | 0.08            | 0.60         | 1.25                  | 0.09            | 68        | 7.5 | 0.7             | 0.67         | 0               | KD           |
| 10   | 1.38                  | 0.08            | 0.65         | 1.30                  | 0.09            | 68        | 7.5 | 0.7             | 0.71         | 0               | KD           |
| 11   | 1.41                  | 0.07            | 0.59         | 1.23                  | 0.10            | 68        | 7.5 | 0.7             | 0.59         | 0               | KD           |
| 12   | 1.43                  | 0.08            | 0.60         | 1.28                  | 0.09            | 67        | 7.6 | 0.8             | 0.57         | 0               | AM           |
| 13   | 1.36                  | 0.09            | 0.59         | 1.21                  | 0.10            |           |     |                 | 0.59         | 0               | AM           |
| 14   | 1.19                  | 0.07            | 0.57         | 1.28                  | 0.09            | 68        | 7.5 | 0.8             | 0.59         | 0               | KD           |
| 15   | 1.18                  | 0.10            | 0.57         | 1.28                  | 0.10            | 69        | 7.5 | 0.7             | 0.58         | 0               | KD           |
| 16   | 1.26                  | 0.08            | 0.61         | 1.26                  | 0.10            | 69        | 7.5 | 0.8             | 0.64         | 0               | KD           |
| 17   | 1.29                  | 0.09            | 0.57         | 1.29                  | 0.10            | 69        | 7.4 | 0.7             | 0.57         | 0               | AM           |
| 18   | 1.23                  | 0.10            | 0.58         | 1.20                  | 0.10            | 69        | 7.4 | 0.7             | 0.53         | 0               | AM           |
| 19   | 1.21                  | 0.06            | 0.61         | 1.23                  | 0.10            | 70        | 7.5 | 0.7             | 0.65         | 0               | KD           |
| 20   | 1.23                  | 0.06            | 0.55         | 1.18                  | 0.08            | 70        | 7.5 | 0.7             | 0.61         | 0               | KD           |
| 21   | 1.20                  | 0.07            | 0.58         | 1.22                  | 0.09            | 70        | 7.4 | 0.7             | 0.57         | 0               | AM           |
| 22   | 1.32                  | 0.08            | 0.55         | 1.28                  | 0.09            | 70        | 7.5 | 0.7             | 0.60         | 0               | AM           |
| 23   | 1.31                  | 0.08            | 0.58         | 1.21                  | 0.08            | 70        | 7.4 | 0.7             | 0.57         | 0               | AM           |
| 24   | 1.16                  | 0.06            | 0.57         | 1.13                  | 0.09            | 71        | 7.4 | 0.8             | 0.57         | 0               | KD           |
| 25   | 1.34                  | 0.07            | 0.61         | 1.22                  | 0.09            | 71        | 7.5 | 0.8             | 0.58         | 0               | KD           |
| 26   | 1.30                  | 0.07            | 0.58         | 1.26                  | 0.09            | 71        | 7.4 | 0.8             | 0.57         | 0               | AM           |
| 27   | 1.31                  | 0.08            | 0.59         | 1.29                  | 0.09            | 70        | 7.4 | 0.8             | 0.56         | 0               | AM           |
| 28   | 1.10                  | 0.09            | 0.58         | 1.24                  | 0.09            | 70        | 7.5 | 0.7             | 0.57         | 0               | KD           |
| 29   | 1.25                  | 0.12            | 0.59         | 1.20                  | 0.14            | 70        | 7.5 | 0.7             | 0.61         | 0               | KD           |
| 30   | 1.28                  | 0.08            | 0.53         | 1.07                  | 0.11            | 70        | 7.5 | 0.8             | 0.54         | 0               | KD           |
| 31   | 1.37                  | 0.15            | 0.61         | 1.12                  | 0.15            | 69        | 7.6 | 0.7             | 0.65         | 0               | CT           |
| AVG. | 1.29                  | 0.08            | 0.59         | 1.23                  | 0.10            | 68        | 7.5 | 0.8             | 0.60         | 0               |              |
| MAX. | 1.43                  | 0.15            | 0.65         | 1.30                  | 0.15            | 71        | 7.6 | 0.8             | 0.71         | 0               |              |
| MIN. | 1.10                  | 0.06            | 0.52         | 1.07                  | 0.07            | 60        | 7.4 | 0.7             | 0.53         | 0               |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

8/3/2021

no analysis

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
AUGUST 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.34                  | 0.10            | 0.59         | 1.13                  | 0.12            | 71        | 7.6 | 0.8             | 0.62         | 0               | CT           |
| 2    | 1.40                  | 0.08            | 0.63         | 1.22                  | 0.10            | 70        | 7.6 | 0.7             | 0.64         | 0               | KD           |
| 3    | 1.31                  | 0.08            | 0.64         | 1.12                  | 0.11            | 71        | 7.5 | 0.8             | 0.66         | 0               | KD           |
| 4    | 1.34                  | 0.09            | 0.59         | 1.19                  | 0.14            | 71        | 7.6 | 0.8             | 0.76         | 0               | CT           |
| 5    | 1.46                  | 0.08            | 0.60         | 1.21                  | 0.11            | 71        | 7.7 | 0.9             | 0.60         | 0               | CT           |
| 6    | 1.33                  | 0.14            | 0.53         | 1.15                  | 0.09            | 71        | 7.6 | 0.8             | 0.59         | 0               | CT           |
| 7    | 1.40                  | 0.11            | 0.58         | 1.14                  | 0.11            | 71        | 7.6 | 0.7             | 0.56         | 0               | RC           |
| 8    | 1.40                  | 0.14            | 0.57         | 1.10                  | 0.12            | 72        | 7.6 | 0.7             | 0.56         | 0               | RC           |
| 9    | 1.33                  | 0.10            | 0.61         | 1.11                  | 0.13            | 71        | 7.6 | 0.7             | 0.62         | 0               | RC           |
| 10   | 1.34                  | 0.11            | 0.61         | 1.08                  | 0.10            | 71        | 7.6 | 0.7             | 0.61         | 0               | RC           |
| 11   | 1.30                  | 0.10            | 0.62         | 1.06                  | 0.11            | 71        | 7.6 | 0.8             | 0.61         | 0               | RC           |
| 12   | 1.31                  | 0.12            | 0.63         | 1.07                  | 0.11            | 71        | 7.6 | 0.7             | 0.61         | 0               | RC           |
| 13   | 1.35                  | 0.14            | 0.64         | 1.15                  | 0.12            | 70        | 7.6 | 0.7             | 0.61         | 0               | RC           |
| 14   | 1.43                  | 0.09            | 0.63         | 1.09                  | 0.11            | 70        | 7.5 | 0.8             | 0.60         | 0               | RC           |
| 15   | 1.33                  | 0.08            | 0.58         | 1.18                  | 0.11            | 69        | 7.5 | 0.7             | 0.65         | 0               | KD           |
| 16   | 1.22                  | 0.09            | 0.62         | 1.20                  | 0.10            | 67        | 7.6 | 0.7             | 0.60         | 0               | RC           |
| 17   | 1.40                  | 0.10            | 0.63         | 1.25                  | 0.09            | 66        | 7.6 | 0.7             | 0.58         | 0               | RC           |
| 18   | 1.37                  | 0.07            | 0.54         | 1.22                  | 0.09            | 66        | 7.5 | 0.7             | 0.62         | 0               | RC           |
| 19   | 1.39                  | 0.12            | 0.58         | 1.21                  | 0.10            | 66        | 7.4 | 0.8             | 0.54         | 0               | RC           |
| 20   | 1.48                  | 0.08            | 0.55         | 1.21                  | 0.11            | 66        | 7.5 | 0.7             | 0.56         | 0               | RC           |
| 21   | 1.29                  | 0.07            | 0.52         | 1.17                  | 0.09            | 66        | 7.6 | 0.7             | 0.61         | 0               | RC           |
| 22   | 1.32                  | 0.09            | 0.59         | 1.20                  | 0.11            | 65        | 7.5 | 0.8             | 0.60         | 0               | RC           |
| 23   | 1.39                  | 0.16            | 0.60         | 1.15                  | 0.12            | 66        | 7.6 | 0.8             | 0.63         | 0               | CT           |
| 24   | 1.24                  | 0.09            | 0.60         | 1.01                  | 0.11            | 68        | 7.6 | 0.9             | 0.61         | 0               | CT           |
| 25   | 1.29                  | 0.12            | 0.57         | 0.99                  | 0.11            | 69        | 7.6 | 0.8             | 0.59         | 0               | RC           |
| 26   | 1.17                  | 0.11            | 0.57         | 0.96                  | 0.11            | 69        | 7.6 | 0.8             | 0.62         | 0               | RC           |
| 27   | 1.05                  | 0.08            | 0.58         | 0.99                  | 0.11            | 70        | 7.6 | 0.8             | 0.63         | 0               | RC           |
| 28   | 1.19                  | 0.08            | 0.60         | 1.20                  | 0.10            | 70        | 7.4 | 0.8             | 0.61         | 0               | AM           |
| 29   | 1.21                  | 0.08            | 0.59         | 1.23                  | 0.10            | 70        | 7.4 | 0.8             | 0.61         | 0               | AM           |
| 30   | 1.29                  | 0.07            | 0.51         | 1.11                  | 0.09            | 69        | 7.6 | 0.8             | 0.57         | 0               | RC           |
| 31   | 1.43                  | 0.07            | 0.59         | 1.21                  | 0.09            | 69        | 7.4 | 0.8             | 0.59         | 0               | AM           |
| AVG. | 1.33                  | 0.10            | 0.59         | 1.14                  | 0.11            | 69        | 7.6 | 0.8             | 0.61         | 0               |              |
| MAX. | 1.48                  | 0.16            | 0.64         | 1.25                  | 0.14            | 72        | 7.7 | 0.9             | 0.76         | 0               |              |
| MIN. | 1.05                  | 0.07            | 0.51         | 0.96                  | 0.09            | 65        | 7.4 | 0.7             | 0.54         | 0               |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

9/1/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
SEPTEMBER 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.38                  | 0.09            | 0.59         | 1.30                  | 0.10            | 67        | 7.4 | 0.8             | 0.58         | 0               | AM           |
| 2    | 1.32                  | 0.09            | 0.60         | 1.27                  | 0.10            | 66        | 7.7 | 0.8             | 0.57         | 0               | AM           |
| 3    | 1.31                  | 0.09            | 0.59         | 1.19                  | 0.10            | 68        | 7.4 | 0.8             | 0.57         | 0               | AM           |
| 4    | 1.25                  | 0.10            | 0.60         | 1.23                  | 0.13            | 71        | 7.4 | 0.8             | 0.65         | 0               | KD           |
| 5    | 1.30                  | 0.10            | 0.59         | 1.31                  | 0.10            | 71        | 7.5 | 0.8             | 0.62         | 0               | KD           |
| 6    | 1.42                  | 0.06            | 0.62         | 1.30                  | 0.07            | 69        | 7.6 | 0.7             | 0.58         | 0               | AM           |
| 7    | 1.40                  | 0.08            | 0.57         | 1.32                  | 0.09            | 69        | 7.4 | 0.8             | 0.56         | 0               | AM           |
| 8    | 1.25                  | 0.10            | 0.64         | 1.23                  | 0.10            | 70        | 7.5 | 0.7             | 0.57         | 0               | KD           |
| 9    | 1.33                  | 0.10            | 0.55         | 1.19                  | 0.10            | 70        | 7.5 | 0.8             | 0.61         | 0               | KD           |
| 10   | 1.25                  | 0.09            | 0.49         | 1.27                  | 0.11            | 69        | 7.6 | 0.8             | 0.50         | 0               | CT           |
| 11   | 1.31                  | 0.10            | 0.57         | 1.24                  | 0.10            | 70        | 7.5 | 0.7             | 0.55         | 0               | AM           |
| 12   | 1.33                  | 0.10            | 0.56         | 1.26                  | 0.10            | 70        | 7.4 | 0.7             | 0.56         | 0               | AM           |
| 13   | 1.32                  | 0.08            | 0.57         | 1.25                  | 0.09            | 70        | 7.5 | 0.7             | 0.61         | 0               | KD           |
| 14   | 1.22                  | 0.08            | 0.61         | 1.30                  | 0.09            | 70        | 7.6 | 0.7             | 0.57         | 0               | KD           |
| 15   | 1.29                  | 0.10            | 0.58         | 1.26                  | 0.13            | 70        | 7.5 | 0.6             | 0.59         | 0               | KD           |
| 16   | 1.16                  | 0.06            | 0.51         | 1.19                  | 0.10            | 70        | 7.6 | 0.8             | 0.57         | 0               | RC           |
| 17   | 1.23                  | 0.09            | 0.55         | 1.22                  | 0.09            | 70        | 7.5 | 0.7             | 0.54         | 0               | KD           |
| 18   | 1.25                  | 0.09            | 0.56         | 1.24                  | 0.10            | 70        | 7.5 | 0.7             | 0.59         | 0               | KD           |
| 19   | 1.24                  | 0.07            | 0.59         | 1.14                  | 0.09            | 70        | 7.5 | 0.7             | 0.57         | 0               | KD           |
| 20   | 1.27                  | 0.07            | 0.57         | 1.18                  | 0.09            | 70        | 7.4 | 0.8             | 0.56         | 0               | AM           |
| 21   | 1.28                  | 0.09            | 0.55         | 1.16                  | 0.08            | 70        | 7.4 | 0.8             | 0.52         | 0               | AM           |
| 22   | 1.25                  | 0.09            | 0.58         | 1.21                  | 0.10            | 70        | 7.5 | 0.7             | 0.54         | 0               | KD           |
| 23   | 1.20                  | 0.09            | 0.55         | 1.18                  | 0.10            | 70        | 7.5 | 0.7             | 0.57         | 0               | KD           |
| 24   | 1.46                  | 0.09            | 0.63         | 1.16                  | 0.10            | 71        | 7.5 | 0.7             | 0.59         | 0               | KD           |
| 25   | 1.31                  | 0.09            | 0.56         | 1.19                  | 0.10            | 69        | 7.5 | 0.7             | 0.57         | 0               | CT           |
| 26   | 1.39                  | 0.07            | 0.57         | 1.31                  | 0.09            | 68        | 7.5 | 0.8             | 0.59         | 0               | CT           |
| 27   | 1.38                  | 0.07            | 0.48         | 1.35                  | 0.08            | 66        | 7.4 | 0.7             | 0.57         | 0               | CT           |
| 28   | 1.39                  | 0.08            | 0.53         | 1.29                  | 0.10            | 68        | 7.4 | 0.8             | 0.56         | 0               | AM           |
| 29   | 1.40                  | 0.11            | 0.51         | 1.30                  | 0.12            | 65        | 7.4 | 0.7             | 0.53         | 0               | CT           |
| 30   | 1.31                  | 0.07            | 0.51         | 1.16                  | 0.09            | 65        | 7.4 | 0.8             | 0.50         | 0               | CT           |
| AVG. | 1.31                  | 0.09            | 0.57         | 1.24                  | 0.10            | 69        | 7.5 | 0.7             | 0.57         | 0               |              |
| MAX. | 1.46                  | 0.11            | 0.64         | 1.35                  | 0.13            | 71        | 7.7 | 0.8             | 0.65         | 0               |              |
| MIN. | 1.16                  | 0.06            | 0.48         | 1.14                  | 0.07            | 65        | 7.4 | 0.6             | 0.50         | 0               |              |

  
Alan L. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

10/11/21

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
OCTOBER 2021

| DATE | LEXINGTON P.S. SUPPLY |                    |                 | DUPAGE P.S. DISCHARGE |                    |              |     |                    |                 |                    | ANALYST INT. |
|------|-----------------------|--------------------|-----------------|-----------------------|--------------------|--------------|-----|--------------------|-----------------|--------------------|--------------|
|      | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | O-PO4<br>(mg/L) | FREE Cl2<br>(mg/L)    | TURBIDITY<br>(ntu) | TEMP<br>(°F) | pH  | Fluoride<br>(mg/L) | O-PO4<br>(mg/L) | P.A.C.<br>(LBS/MG) |              |
| 1    | 1.22                  | 0.06               | 0.52            | 1.19                  | 0.07               | 66           | 7.5 | 0.8                | 0.53            | 0                  | CT           |
| 2    | 1.47                  | 0.06               | 0.52            | 1.27                  | 0.07               | 66           | 7.4 | 0.7                | 0.53            | 0                  | RC           |
| 3    | 1.43                  | 0.07               | 0.58            | 1.26                  | 0.07               | 66           | 7.5 | 0.7                | 0.52            | 0                  | RC           |
| 4    | 1.41                  | 0.10               | 0.56            | 1.24                  | 0.09               | 67           | 7.6 | 0.7                | 0.55            | 0                  | CT           |
| 5    | 1.31                  | 0.09               | 0.62            | 1.24                  | 0.09               | 67           | 7.4 | 0.9                | 0.59            | 0                  | CT           |
| 6    | 1.26                  | 0.08               | 0.56            | 1.15                  | 0.10               | 66           | 7.4 | 0.8                | 0.52            | 0                  | RC           |
| 7    | 1.23                  | 0.07               | 0.51            | 1.22                  | 0.08               | 66           | 7.4 | 0.7                | 0.53            | 0                  | RC           |
| 8    | 1.28                  | 0.09               | 0.60            | 1.21                  | 0.09               | 66           | 7.4 | 0.8                | 0.48            | 0                  | RC           |
| 9    | 1.28                  | 0.07               | 0.60            | 1.20                  | 0.10               | 67           | 7.4 | 0.8                | 0.55            | 0                  | RC           |
| 10   | 1.36                  | 0.07               | 0.55            | 1.29                  | 0.09               | 66           | 7.4 | 0.7                | 0.62            | 0                  | KD           |
| 11   | 1.23                  | 0.08               | 0.46            | 1.05                  | 0.08               | 68           | 7.5 | 0.7                | 0.49            | 0                  | RC           |
| 12   | 1.13                  | 0.09               | 0.63            | 0.99                  | 0.09               | 69           | 7.5 | 0.7                | 0.51            | 0                  | RC           |
| 13   | 1.38                  | 0.09               | 0.54            | 1.26                  | 0.09               | 69           | 7.6 | 0.7                | 0.56            | 0                  | CT           |
| 14   | 1.49                  | 0.09               | 0.67            | 1.07                  | 0.10               | 68           | 7.4 | 0.6                | 0.59            | 0                  | CT           |
| 15   | 1.19                  | 0.11               | 0.61            | 1.05                  | 0.09               | 68           | 7.5 | 0.8                | 0.58            | 0                  | CT           |
| 16   | 1.07                  | 0.10               | 0.61            | 1.08                  | 0.09               | 67           | 7.5 | 0.8                | 0.58            | 0                  | RC           |
| 17   | 1.30                  | 0.09               | 0.54            | 1.08                  | 0.10               | 69           | 7.5 | 0.8                | 0.57            | 0                  | RC           |
| 18   | 1.40                  | 0.10               | 0.62            | 1.05                  | 0.10               | 70           | 7.4 | 0.8                | 0.54            | 0                  | CT           |
| 19   | 1.25                  | 0.10               | 0.54            | 0.91                  | 0.10               | 70           | 7.6 | 0.8                | 0.58            | 0                  | CT           |
| 20   | 1.06                  | 0.11               | 0.55            | 1.11                  | 0.11               | 68           | 7.5 | 0.8                | 0.54            | 0                  | RC           |
| 21   | 1.37                  | 0.07               | 0.49            | 1.22                  | 0.11               | 68           | 7.5 | 0.8                | 0.56            | 0                  | RC           |
| 22   | 1.44                  | 0.08               | 0.63            | 1.12                  | 0.10               | 67           | 7.5 | 0.7                | 0.58            | 0                  | RC           |
| 23   | 1.32                  | 0.09               | 0.58            | 1.21                  | 0.09               | 66           | 7.3 | 0.8                | 0.56            | 0                  | AM           |
| 24   | 1.26                  | 0.08               | 0.54            | 1.25                  | 0.09               | 66           | 7.3 | 0.8                | 0.54            | 0                  | AM           |
| 25   | 1.38                  | 0.06               | 0.49            | 1.10                  | 0.08               | 66           | 7.5 | 0.8                | 0.56            | 0                  | RC           |
| 26   | 1.00                  | 0.10               | 0.55            | 1.19                  | 0.11               | 67           | 7.5 | 0.8                | 0.58            | 0                  | RC           |
| 27   | 1.41                  | 0.08               | 0.56            | 1.21                  | 0.09               | 67           | 7.3 | 0.8                | 0.54            | 0                  | AM           |
| 28   | 1.36                  | 0.07               | 0.53            | 1.18                  | 0.10               | 66           | 7.2 | 0.8                | 0.55            | 0                  | AM           |
| 29   | 1.35                  | 0.07               | 0.51            | 1.13                  | 0.09               | 65           | 7.3 | 0.8                | 0.56            | 0                  | AM           |
| 30   | 1.31                  | 0.08               | 0.53            | 1.16                  | 0.09               | 63           | 7.4 | 0.8                | 0.54            | 0                  | KD           |
| 31   | 1.16                  | 0.09               | 0.57            | 1.24                  | 0.08               | 62           | 7.4 | 0.8                | 0.63            | 0                  | KD           |
| AVG. | 1.29                  | 0.08               | 0.56            | 1.16                  | 0.09               | 67           | 7.4 | 0.8                | 0.55            | 0                  |              |
| MAX. | 1.49                  | 0.11               | 0.67            | 1.29                  | 0.11               | 70           | 7.6 | 0.9                | 0.63            | 0                  |              |
| MIN. | 1.00                  | 0.06               | 0.46            | 0.91                  | 0.07               | 62           | 7.2 | 0.6                | 0.48            | 0                  |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

11/1/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
NOVEMBER 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.46                  | 0.07            | 0.60         | 1.21                  | 0.08            | 61        | 7.4 | 0.7             | 0.59         | 0               | KD           |
| 2    | 1.39                  | 0.07            | 0.57         | 1.26                  | 0.09            | 61        | 7.2 | 0.8             | 0.57         | 0               | AM           |
| 3    | 1.24                  | 0.05            | 0.56         | 1.05                  | 0.08            | 61        | 7.3 | 0.7             | 0.59         | 0               | KD           |
| 4    | 1.39                  | 0.07            | 0.60         | 1.26                  | 0.09            | 60        | 7.3 | 0.8             | 0.57         | 0               | KD           |
| 5    | 1.26                  | 0.06            | 0.48         | 1.25                  | 0.08            | 59        | 7.3 | 0.7             | 0.52         | 0               | KD           |
| 6    | 1.28                  | 0.08            | 0.50         | 1.23                  | 0.07            | 58        | 7.3 | 0.7             | 0.51         | 0               | AM           |
| 7    | 1.21                  | 0.07            | 0.53         | 1.28                  | 0.07            | 58        | 7.2 | 0.7             | 0.54         | 0               | AM           |
| 8    | 1.44                  | 0.07            | 0.63         | 1.17                  | 0.08            | 58        | 7.2 | 0.8             | 0.59         | 0               | KD           |
| 9    | 1.46                  | 0.07            | 0.59         | 1.28                  | 0.07            | 58        | 7.2 | 0.7             | 0.56         | 0               | KD           |
| 10   | 1.49                  | 0.08            | 0.54         | 1.29                  | 0.08            | 57        | 7.2 | 0.8             | 0.56         | 0               | AM           |
| 11   | 1.38                  | 0.08            | 0.57         | 1.27                  | 0.08            | 58        | 7.2 | 0.9             | 0.58         | 0               | AM           |
| 12   | 1.40                  | 0.06            | 0.52         | 1.30                  | 0.09            | 58        | 7.1 | 0.9             | 0.56         | 0               | AM           |
| 13   | 1.36                  | 0.06            | 0.58         | 1.20                  | 0.07            | 58        | 7.2 | 0.8             | 0.65         | 0               | KD           |
| 14   | 1.48                  | 0.07            | 0.62         | 1.19                  | 0.08            | 58        | 7.1 | 0.8             | 0.58         | 0               | KD           |
| 15   | 1.37                  | 0.07            | 0.64         | 1.27                  | 0.09            | 57        | 7.1 | 0.8             | 0.59         | 0               | AM           |
| 16   | 1.32                  | 0.08            | 0.57         | 1.25                  | 0.07            | 56        | 7.1 | 0.8             | 0.58         | 0               | AM           |
| 17   | 1.42                  | 0.07            | 0.61         | 1.23                  | 0.07            | 56        | 7.1 | 0.8             | 0.63         | 0               | KD           |
| 18   | 1.46                  | 0.06            | 0.59         | 1.23                  | 0.08            | 57        | 7.1 | 0.8             | 0.61         | 0               | KD           |
| 19   | 1.41                  | 0.07            | 0.62         | 1.24                  | 0.07            | 56        | 7.1 | 0.8             | 0.60         | 0               | KD           |
| 20   | 1.42                  | 0.07            | 0.58         | 1.25                  | 0.07            | 57        | 7.1 | 0.7             | 0.63         | 0               | CT           |
| 21   | 1.39                  | 0.06            | 0.63         | 1.31                  | 0.07            | 55        | 7.2 | 1.0             | 0.61         | 0               | CT           |
| 22   | 1.42                  | 0.07            | 0.60         | 1.27                  | 0.07            | 54        | 7.0 | 0.9             | 0.59         | 0               | KD           |
| 23   | 1.40                  | 0.07            | 0.61         | 1.24                  | 0.08            | 54        | 7.1 | 0.9             | 0.58         | 0               | KD           |
| 24   | 1.44                  | 0.05            | 0.61         | 1.04                  | 0.15            | 60        | 7.1 | 0.9             | 0.62         | 0               | CT           |
| 25   | 1.42                  | 0.07            | 0.57         | 1.16                  | 0.12            | 57        | 7.1 | 0.7             | 0.56         | 0               | CT           |
| 26   | 1.36                  | 0.05            | 0.51         | 1.13                  | 0.10            | 56        | 7.0 | 0.8             | 0.59         | 0               | CT           |
| 27   | 1.21                  | 0.07            | 0.56         | 1.17                  | 0.09            | 56        | 7.3 | 0.8             | 0.60         | 0               | RC           |
| 28   | 1.36                  | 0.05            | 0.66         | 1.17                  | 0.12            | 57        | 7.3 | 0.8             | 0.62         | 0               | RC           |
| 29   | 1.41                  | 0.06            | 0.61         | 1.19                  | 0.11            | 55        | 7.0 | 0.8             | 0.58         | 0               | CT           |
| 30   | 1.23                  | 0.07            | 0.59         | 1.22                  | 0.11            | 55        | 7.1 | 0.8             | 1.02         | 0               | CT           |
| 31   |                       |                 |              |                       |                 |           |     |                 |              |                 |              |
| AVG. | 1.38                  | 0.07            | 0.58         | 1.22                  | 0.09            | 57        | 7.2 | 0.8             | 0.60         | 0               |              |
| MAX. | 1.49                  | 0.08            | 0.66         | 1.31                  | 0.15            | 61        | 7.4 | 1.0             | 1.02         | 0               |              |
| MIN. | 1.21                  | 0.05            | 0.48         | 1.04                  | 0.07            | 54        | 7.0 | 0.7             | 0.51         | 0               |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

12/1/2021

DUPAGE WATER COMMISSION  
PWS FACILITY ID# - IL435400  
MONTHLY OPERATIONS REPORT  
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS  
DECEMBER 2021

| DATE | LEXINGTON P.S. SUPPLY |                 |              | DUPAGE P.S. DISCHARGE |                 |           |     |                 |              |                 | ANALYST INT. |
|------|-----------------------|-----------------|--------------|-----------------------|-----------------|-----------|-----|-----------------|--------------|-----------------|--------------|
|      | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | O-PO4 (mg/L) | FREE Cl2 (mg/L)       | TURBIDITY (ntu) | TEMP (°F) | pH  | Fluoride (mg/L) | O-PO4 (mg/L) | P.A.C. (LBS/MG) |              |
| 1    | 1.44                  | 0.07            | 0.62         | 1.25                  | 0.10            | 54        | 7.2 | 0.8             | 0.62         | 0               | RC           |
| 2    | 1.42                  | 0.06            | 0.61         | 1.24                  | 0.09            | 54        | 7.3 | 0.8             | 0.63         | 0               | RC           |
| 3    | 1.47                  | 0.05            | 0.62         | 1.22                  | 0.10            | 55        | 7.2 | 0.9             | 0.60         | 0               | RC           |
| 4    | 1.39                  | 0.05            | 0.61         | 1.25                  | 0.10            | 55        | 7.0 | 0.8             | 0.62         | 0               | CT           |
| 5    | 1.47                  | 0.06            | 0.62         | 1.23                  | 0.11            | 54        | 7.0 | 0.9             | 0.57         | 0               | CT           |
| 6    | 1.36                  | 0.06            | 0.57         | 1.25                  | 0.09            | 54        | 7.2 | 0.8             | 0.68         | 0               | RC           |
| 7    | 1.35                  | 0.06            | 0.58         | 1.28                  | 0.09            | 54        | 7.1 | 0.8             | 0.63         | 0               | RC           |
| 8    | 1.43                  | 0.07            | 0.50         | 1.17                  | 0.09            | 54        | 7.0 | 0.9             | 0.56         | 0               | CT           |
| 9    | 1.40                  | 0.06            | 0.55         | 1.22                  | 0.11            | 54        | 7.0 | 0.9             | 0.58         | 0               | CT           |
| 10   | 1.35                  | 0.07            | 0.58         | 1.28                  | 0.11            | 53        | 7.3 | 0.8             | 0.53         | 0               | RC           |
| 11   | 1.43                  | 0.07            | 0.59         | 1.22                  | 0.10            | 53        | 7.1 | 0.8             | 0.61         | 0               | RC           |
| 12   | 1.43                  | 0.07            | 0.63         | 1.22                  | 0.11            | 53        | 7.2 | 0.8             | 0.57         | 0               | RC           |
| 13   | 1.51                  | 0.07            | 0.64         | 1.26                  | 0.10            | 53        | 6.9 | 0.9             | 0.50         | 0               | CT           |
| 14   | 1.46                  | 0.08            | 0.66         | 1.27                  | 0.11            | 54        | 7.2 | 0.8             | 0.59         | 0               | CT           |
| 15   | 1.61                  | 0.06            | 0.54         | 1.30                  | 0.10            | 52        | 7.1 | 0.9             | 0.59         | 0               | RC           |
| 16   | 1.45                  | 0.06            | 0.52         | 1.40                  | 0.09            | 53        | 7.2 | 0.8             | 0.55         | 0               | RC           |
| 17   | 1.29                  | 0.07            | 0.53         | 1.26                  | 0.11            | 52        | 7.2 | 0.8             | 0.55         | 0               | RC           |
| 18   | 1.44                  | 0.05            | 0.48         | 1.36                  | 0.13            | 52        | 7.2 | 0.8             | 0.48         | 0               | RC           |
| 19   | 1.48                  | 0.05            | 0.53         | 1.38                  | 0.09            | 52        | 7.1 | 0.8             | 0.50         | 0               | AM           |
| 20   | 1.36                  | 0.05            | 0.50         | 1.25                  | 0.09            | 52        | 7.2 | 0.8             | 0.55         | 0               | RC           |
| 21   | 1.42                  | 0.06            | 0.50         | 1.26                  | 0.09            | 53        | 7.1 | 0.8             | 0.50         | 0               | RC           |
| 22   | 1.49                  | 0.06            | 0.52         | 1.34                  | 0.07            | 52        | 7.2 | 0.8             | 0.52         | 0               | AM           |
| 23   | 1.40                  | 0.07            | 0.55         | 1.30                  | 0.08            | 53        | 7.1 | 0.7             | 0.57         | 0               | AM           |
| 24   | 1.43                  | 0.08            | 0.53         | 1.28                  | 0.09            | 52        | 7.1 | 0.8             | 0.56         | 0               | AM           |
| 25   | 1.39                  | 0.09            | 0.53         | 1.25                  | 0.10            | 53        | 7.0 | 0.8             | 0.52         | 0               | AM           |
| 26   | 1.31                  | 0.06            | 0.64         | 1.25                  | 0.11            | 54        | 7.0 | 0.9             | 0.56         | 0               | CT           |
| 27   | 1.42                  | 0.07            | 0.60         | 1.27                  | 0.10            | 53        | 7.0 | 0.8             | 0.59         | 0               | KD           |
| 28   | 1.32                  | 0.06            | 0.55         | 1.23                  | 0.09            | 52        | 7.2 | 0.7             | 0.53         | 0               | KD           |
| 29   | 1.33                  | 0.07            | 0.57         | 1.27                  | 0.09            | 52        | 7.1 | 0.8             | 0.55         | 0               | KD           |
| 30   | 1.39                  | 0.07            | 0.58         | 1.12                  | 0.10            | 53        | 7.2 | 0.8             | 0.59         | 0               | KD           |
| 31   | 1.30                  | 0.07            | 0.56         | 1.31                  | 0.10            | 52        | 7.1 | 0.8             | 0.56         | 0               | KD           |
| AVG. | 1.41                  | 0.06            | 0.57         | 1.26                  | 0.10            | 53        | 7.1 | 0.8             | 0.57         | 0               |              |
| MAX. | 1.61                  | 0.09            | 0.66         | 1.40                  | 0.13            | 55        | 7.3 | 0.9             | 0.68         | 0               |              |
| MIN. | 1.29                  | 0.05            | 0.48         | 1.12                  | 0.07            | 52        | 6.9 | 0.7             | 0.48         | 0               |              |

Alan E. Stark, Coordinating Engineer  
Illinois ROINC # 84789479

Date

11/10/2022