

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
JANUARY 2026

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.41	0.06	2.25	1.31	0.07	51	7.6	0.8	2.28	0	AM
2	1.29	0.07	2.30	1.28	0.07	51	7.5	0.7	2.20	0	AM
3	1.23	0.07	2.21	1.25	0.11	52	7.7	0.6	2.17	0	JS
4	1.36	0.06	2.20	1.36	0.11	54	7.7	0.6	2.29	0	JS
5	1.32	0.08	2.22	1.29	0.09	51	7.6	0.8	2.18	0	AM
6	1.35	0.05	2.18	1.23	0.11	50	7.6	0.7	2.25	0	AM
7	1.41	0.07	2.34	1.32	0.10	51	7.6	0.7	2.30	0	JS
8	1.36	0.06	2.23	1.29	0.10	52	7.6	0.7	2.31	0	JS
9	1.43	0.08	2.32	1.38	0.11	53	7.7	0.6	2.29	0	JS
10	1.47	0.05	2.30	1.27	0.11	49	7.5	0.7	2.30	0	KD
11	1.37	0.05	2.21	1.23	0.11	51	7.5	0.6	2.15	0	KD
12	1.36	0.06	2.37	1.31	0.11	51	7.6	0.7	2.20	0	JS
13	1.32	0.07	2.30	1.28	0.11	53	7.7	0.6	2.28	0	JS
14	1.33	0.08	2.08	1.24	0.11	48	7.5	0.7	2.21	0	KD
15	1.45	0.05	2.27	1.26	0.09	46	7.4	0.7	2.21	0	KD
16	1.36	0.05	2.28	1.27	0.09	48	7.4	0.8	2.28	0	KD
17	1.44	0.08	2.28	1.17	0.12	52	7.8	0.7	2.26	0	RC
18	1.39	0.07	2.22	1.16	0.11	51	7.4	0.6	2.32	0	KD
19	1.38	0.06	2.36	1.13	0.12	52	7.4	0.7	2.21	0	KD
20	1.29	0.07	2.15	1.15	0.13	50	7.4	0.8	2.25	0	KD
21	1.39	0.07	2.15	1.17	0.14	52	7.7	0.7	2.12	0	RC
22	1.45	0.07	2.18	1.13	0.11	60	7.6	0.7	2.19	0	RC
23	1.46	0.07	2.26	1.22	0.13	57	7.6	0.7	2.17	0	RC
24	1.35	0.06	2.21	1.14	0.12	54	7.4	0.6	2.31	0	KD
25	1.30	0.05	2.30	1.13	0.12	54	7.4	0.6	2.27	0	KD
26	1.38	0.06	2.22	1.35	0.13	57	7.5	0.7	2.38	0	RC
27	1.32	0.06	2.25	1.08	0.10	51	7.4	0.6	2.23	0	KD
28	1.42	0.06	2.25	1.08	0.13	52	7.4	0.5	2.21	0	KD
29	1.46	0.07	2.18	1.34	0.08	51	7.4	0.7	2.18	0	KD
30	1.59	0.12	2.22	1.44	0.14	49	7.4	0.7	2.14	0	KD
31	1.52	0.07	2.08	1.47	0.10	49	7.3	0.8	2.25	0	RC
AVG.	1.39	0.07	2.24	1.25	0.11	52	7.5	0.7	2.24	0	
MAX.	1.59	0.12	2.37	1.47	0.14	60	7.8	0.8	2.38	0	
MIN.	1.23	0.05	2.08	1.08	0.07	46	7.3	0.5	2.12	0	


Ross C. Bostick, Manager of Water Operation
Illinois ROINC # 194171377

2/10/26
Date

Mike Weed, Operations Supervisor
Illinois ROINC # 186860234
Date



DUPAGE WATER COMMISSION
 PWS FACILITY ID# - IL435400
 MONTHLY OPERATIONS REPORT
 FEBRUARY 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

DATE	CHICAGO SUPPLY				DUPAGE DISCHARGE						
	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.41	0.07	1.98	0.00	1.4	0.10	51	7.4	0.7	2.08	RC
2	1.5	0.06	2.17	0.00	1.29	0.11	56	7.4	0.7	2.13	KD
3	1.35	0.09	2.21	0.00	1.4	0.11	56	7.4	0.7	2.18	KD
4	1.37	0.07	2.18	0.00	1.4	0.08	54	7.4	0.7	2.17	RC
5	1.43	0.05	2.23	0.00	1.42	0.08	56	7.4	0.7	2.24	RC
6	1.37	0.07	2.29	0.00	1.37	0.06	56	7.4	0.7	2.21	RC
7	1.43	0.08	2.21	0.00	1.41	0.10	56	7.4	0.7	2.22	AM
8	1.52	0.06	2.14	0.00	1.48	0.07	54	7.5	0.7	2.18	AM
9	1.34	0.05	2.12	0.00	1.41	0.12	49	7.5	0.7	2.14	AM
10	1.44	0.05	2.22	0.00	1.38	0.06	48	7.4	0.7	2.16	RC
11	1.39	0.06	2.17	0.00	1.46	0.09	46	7.5	0.7	2.19	AM
12	1.45	0.07	2.20	0.00	1.45	0.10	46	7.5	0.7	2.10	AM
13	1.45	0.07	2.23	0.00	1.37	0.08	46	7.6	0.7	2.14	AM
14	1.45	0.06	2.25	0.00	1.42	0.06	47	7.6	0.7	2.18	JS
15	1.38	0.06	2.20	0.00	1.36	0.08	48	7.5	0.7	2.12	JS
16	1.41	0.08	2.17	0.00	1.28	0.08	47	7.6	0.7	2.09	AM
17	1.49	0.08	2.14	0.00	1.31	0.06	46	7.5	0.7	2.11	AM
18	1.33	0.05	2.18	0.00	1.31	0.06	48	7.5	0.7	2.20	JS
19	1.46	0.05	2.20	0.00	1.4	0.06	49	7.5	0.6	2.21	JS
20	1.43	0.06	2.20	0.00	1.43	0.07	50	7.5	0.7	2.19	JS
21	1.4	0.08	2.02	0.00	1.38	0.07	53	7.5	0.7	2.22	AM
22	1.48	0.06	2.13	0.00	1.31	0.08	50	7.6	0.7	2.10	AM
23	1.34	0.06	2.14	0.00	1.24	0.09	52	7.5	0.7	2.11	JS
24	1.44	0.07	2.11	0.00	1.4	0.07	52	7.5	0.7	2.06	JS
25	1.38	0.07	2.02	0.00	1.45	0.09	49	7.6	0.7	1.44	AM
26	1.51	0.06	1.46	0.00	1.43	0.11	46	7.5	0.7	1.38	AM
27	1.55	0.05	1.60	0.00	1.4	0.10	46	7.6	0.7	1.48	AM
28	1.46	0.06	1.47	0.00	1.43	0.08	49	7.5	0.7	1.36	JS
29											
30											
31											
AVG.	1.43	0.06	2.09	0.00	1.39	0.08	50.21	7.49	0.70	2.05	
MAX.	1.55	0.09	2.29	0.00	1.48	0.12	56.00	7.60	0.70	2.24	
MIN.	1.33	0.05	1.46	0.00	1.24	0.06	46.00	7.40	0.60	1.36	

[Redacted Signature]

Ross C. Bostick, Manager of Water Operations
 ROINC - Certification No. 194171377

3/9/2026

Date