

DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS
JANUARY 2026

DATE	LEXINGTON P.S. SUPPLY			DUPAGE P.S. DISCHARGE							ANALYST INT.
	FREE Cl2 (mg/L)	TURBIDITY (ntu)	O-PO4 (mg/L)	FREE Cl2 (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO4 (mg/L)	P.A.C. (LBS/MG)	
1	1.41	0.06	2.25	1.31	0.07	51	7.6	0.8	2.28	0	AM
2	1.29	0.07	2.30	1.28	0.07	51	7.5	0.7	2.20	0	AM
3	1.23	0.07	2.21	1.25	0.11	52	7.7	0.6	2.17	0	JS
4	1.36	0.06	2.20	1.36	0.11	54	7.7	0.6	2.29	0	JS
5	1.32	0.08	2.22	1.29	0.09	51	7.6	0.8	2.18	0	AM
6	1.35	0.05	2.18	1.23	0.11	50	7.6	0.7	2.25	0	AM
7	1.41	0.07	2.34	1.32	0.10	51	7.6	0.7	2.30	0	JS
8	1.36	0.06	2.23	1.29	0.10	52	7.6	0.7	2.31	0	JS
9	1.43	0.08	2.32	1.38	0.11	53	7.7	0.6	2.29	0	JS
10	1.47	0.05	2.30	1.27	0.11	49	7.5	0.7	2.30	0	KD
11	1.37	0.05	2.21	1.23	0.11	51	7.5	0.6	2.15	0	KD
12	1.36	0.06	2.37	1.31	0.11	51	7.6	0.7	2.20	0	JS
13	1.32	0.07	2.30	1.28	0.11	53	7.7	0.6	2.28	0	JS
14	1.33	0.08	2.08	1.24	0.11	48	7.5	0.7	2.21	0	KD
15	1.45	0.05	2.27	1.26	0.09	46	7.4	0.7	2.21	0	KD
16	1.36	0.05	2.28	1.27	0.09	48	7.4	0.8	2.28	0	KD
17	1.44	0.08	2.28	1.17	0.12	52	7.8	0.7	2.26	0	RC
18	1.39	0.07	2.22	1.16	0.11	51	7.4	0.6	2.32	0	KD
19	1.38	0.06	2.36	1.13	0.12	52	7.4	0.7	2.21	0	KD
20	1.29	0.07	2.15	1.15	0.13	50	7.4	0.8	2.25	0	KD
21	1.39	0.07	2.15	1.17	0.14	52	7.7	0.7	2.12	0	RC
22	1.45	0.07	2.18	1.13	0.11	60	7.6	0.7	2.19	0	RC
23	1.46	0.07	2.26	1.22	0.13	57	7.6	0.7	2.17	0	RC
24	1.35	0.06	2.21	1.14	0.12	54	7.4	0.6	2.31	0	KD
25	1.30	0.05	2.30	1.13	0.12	54	7.4	0.6	2.27	0	KD
26	1.38	0.06	2.22	1.35	0.13	57	7.5	0.7	2.38	0	RC
27	1.32	0.06	2.25	1.08	0.10	51	7.4	0.6	2.23	0	KD
28	1.42	0.06	2.25	1.08	0.13	52	7.4	0.5	2.21	0	KD
29	1.46	0.07	2.18	1.34	0.08	51	7.4	0.7	2.18	0	KD
30	1.59	0.12	2.22	1.44	0.14	49	7.4	0.7	2.14	0	KD
31	1.52	0.07	2.08	1.47	0.10	49	7.3	0.8	2.25	0	RC
AVG.	1.39	0.07	2.24	1.25	0.11	52	7.5	0.7	2.24	0	
MAX.	1.59	0.12	2.37	1.47	0.14	60	7.8	0.8	2.38	0	
MIN.	1.23	0.05	2.08	1.08	0.07	46	7.3	0.5	2.12	0	

Ross C. Bostick, Manager of Water Operation
Illinois ROINC # 194171377

2/10/26

Date

Mike Weed, Operations Supervisor
Illinois ROINC # 186860234

Date



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
FEBRUARY 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

CHICAGO SUPPLY					DUPAGE DISCHARGE						
DATE	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.41	0.07	1.98	0.00	1.4	0.10	51	7.4	0.7	2.08	RC
2	1.5	0.06	2.17	0.00	1.29	0.11	56	7.4	0.7	2.13	KD
3	1.35	0.09	2.21	0.00	1.4	0.11	56	7.4	0.7	2.18	KD
4	1.37	0.07	2.18	0.00	1.4	0.08	54	7.4	0.7	2.17	RC
5	1.43	0.05	2.23	0.00	1.42	0.08	56	7.4	0.7	2.24	RC
6	1.37	0.07	2.29	0.00	1.37	0.06	56	7.4	0.7	2.21	RC
7	1.43	0.08	2.21	0.00	1.41	0.10	56	7.4	0.7	2.22	AM
8	1.52	0.06	2.14	0.00	1.48	0.07	54	7.5	0.7	2.18	AM
9	1.34	0.05	2.12	0.00	1.41	0.12	49	7.5	0.7	2.14	AM
10	1.44	0.05	2.22	0.00	1.38	0.06	48	7.4	0.7	2.16	RC
11	1.39	0.06	2.17	0.00	1.46	0.09	46	7.5	0.7	2.19	AM
12	1.45	0.07	2.20	0.00	1.45	0.10	46	7.5	0.7	2.10	AM
13	1.45	0.07	2.23	0.00	1.37	0.08	46	7.6	0.7	2.14	AM
14	1.45	0.06	2.25	0.00	1.42	0.06	47	7.6	0.7	2.18	JS
15	1.38	0.06	2.20	0.00	1.36	0.08	48	7.5	0.7	2.12	JS
16	1.41	0.08	2.17	0.00	1.28	0.08	47	7.6	0.7	2.09	AM
17	1.49	0.08	2.14	0.00	1.31	0.06	46	7.5	0.7	2.11	AM
18	1.33	0.05	2.18	0.00	1.31	0.06	48	7.5	0.7	2.20	JS
19	1.46	0.05	2.20	0.00	1.4	0.06	49	7.5	0.6	2.21	JS
20	1.43	0.06	2.20	0.00	1.43	0.07	50	7.5	0.7	2.19	JS
21	1.4	0.08	2.02	0.00	1.38	0.07	53	7.5	0.7	2.22	AM
22	1.48	0.06	2.13	0.00	1.31	0.08	50	7.6	0.7	2.10	AM
23	1.34	0.06	2.14	0.00	1.24	0.09	52	7.5	0.7	2.11	JS
24	1.44	0.07	2.11	0.00	1.4	0.07	52	7.5	0.7	2.06	JS
25	1.38	0.07	2.02	0.00	1.45	0.09	49	7.6	0.7	1.44	AM
26	1.51	0.06	1.46	0.00	1.43	0.11	46	7.5	0.7	1.38	AM
27	1.55	0.05	1.60	0.00	1.4	0.10	46	7.6	0.7	1.48	AM
28	1.46	0.06	1.47	0.00	1.43	0.08	49	7.5	0.7	1.36	JS
29											
30											
31											
AVG.	1.43	0.06	2.09	0.00	1.39	0.08	50.21	7.49	0.70	2.05	
MAX.	1.55	0.09	2.29	0.00	1.48	0.12	56.00	7.60	0.70	2.24	
MIN.	1.33	0.05	1.46	0.00	1.24	0.06	46.00	7.40	0.60	1.36	

Ross C. Bostick, Manager of Water Operations
 ROINC - Certification No. 194171377

3/9/2026

Date



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
MARCH 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

CHICAGO SUPPLY					DUPAGE DISCHARGE						
DATE	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.54	0.07	1.52	0.00	1.56	0.07	48	7.5	0.7	1.47	JS
2	1.54	0.05	1.40	0.00	1.36	0.07	47	7.6	0.7	1.41	AM
3	1.52	0.05	2.16	0.00	1.33	0.08	47	7.6	0.6	2.12	AM
4	1.51	0.06	2.19	0.00	1.41	0.06	50	7.5	0.7	2.10	JS
5	1.39	0.06	2.20	0.00	1.38	0.07	50	7.5	0.7	2.13	JS
6	1.45	0.08	2.14	0.00	1.43	0.08	49	7.5	0.7	2.07	JS
7	1.42	0.06	2.11	0.00	1.33	0.09	49	7.4	0.7	2.04	KD
8	1.39	0.06	2.21	0.00	1.37	0.08	50	7.4	0.7	2.10	KD
9	1.32	0.06	2.06	0.00	1.34	0.08	51	7.5	0.7	2.10	JS
10	1.38	0.06	2.19	0.00	1.36	0.07	50	7.6	0.7	2.08	JS
11	1.3	0.07	2.06	0.00	1.29	0.09	48	7.6	0.7	2.11	KD
12	1.44	0.12	2.16	0.00	1.32	0.11	48	7.7	0.7	1.91	KD
13	1.38	0.06	2.20	0.00	1.38	0.10	50	7.6	0.7	2.15	KD
14	1.36	0.06	2.07	0.00	1.28	0.11	52	7.4	0.7	2.17	RC
15	1.35	0.05	2.20	0.00	1.35	0.06	52	7.4	0.7	2.22	RC
16	1.35	0.06	1.96	0.00	1.26	0.07	52	7.6	0.7	2.10	KD
17	1.36	0.09	1.97	0.00	1.36	0.08	51	7.6	0.7	2.12	KD
18	1.37	0.05	2.06	0.00	1.32	0.07	52	7.4	0.7	2.00	RC
19	1.41	0.05	2.18	0.00	1.38	0.05	52	7.4	0.6	2.19	RC
20	1.4	0.05	2.27	0.00	1.38	0.05	51	7.4	0.6	2.29	RC
21	1.24	0.04	2.54	0.00	1.36	0.08	52	7.4	0.6	2.25	KD
22	1.36	0.05	2.19	0.00	1.3	0.08	53	7.4	0.5	2.23	KD
23	1.35	0.05	2.08	0.00	1.27	0.07	54	7.4	0.6	2.15	KD
24	1.33	0.06	2.10	0.00	1.34	0.08	51	7.4	0.7	2.18	RC
25	1.51	0.05	2.17	0.00	1.25	0.09	52	7.4	0.6	2.05	KD
26	1.43	0.05	2.42	0.00	1.33	0.06	49	7.4	0.6	2.44	KD
27	1.42	0.09	2.26	0.00	1.29	0.08	52	7.5	0.7	2.25	KD
28	1.53	0.07	1.62	0.00	1.43	0.08	54	7.4	0.7	1.60	RC
29	1.52	0.05	1.57	0.00	1.48	0.07	54	7.3	0.8	1.51	RC
30	1.27	0.08	1.53	0.00	1.34	0.09	54	7.5	0.7	1.42	KD
31	1.3	0.07	1.54	0.00	1.41	0.10	51	7.5	0.7	1.42	KD
AVG.	1.40	0.06	2.04	0.00	1.35	0.08	51	7.5	0.7	2.01	
MAX.	1.54	0.12	2.54	0.00	1.56	0.11	54	7.7	0.8	2.44	
MIN.	1.24	0.04	1.40	0.00	1.25	0.05	47	7.3	0.5	1.41	

Ross C. Bostick, Manager of Water Operations
ROINC - Certification No. 194171377

4/6/2026

Date



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
APRIL 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

CHICAGO SUPPLY					DUPAGE DISCHARGE						
DATE	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.49	0.05	1.61	0.00	1.43	0.07	53	7.4	0.7	1.61	R.C.
2	1.38	0.05	1.59	0.00	1.46	0.07	54	7.4	0.7	1.49	R.C.
3	1.37	0.06	1.61	0.00	1.37	0.06	56	7.4	0.8	2.11	R.C.
4	1.43	0.05	2.16	0.00	1.38	0.09	56	7.4	0.8	2.16	R.C.
5	1.39	0.06	2.24	0.00	1.39	0.06	58	7.4	0.7	2.13	R.C.
6	1.34	0.05	2.22	0.00	1.37	0.08	58	7.4	0.8	2.20	R.C.
7	1.36	0.05	2.04	0.00	1.32	0.06	56	7.4	0.7	2.12	R.C.
8	1.33	0.06	2.08	0.00	1.33	0.06	55	7.3	0.8	2.09	A.M.
9	1.39	0.06	2.26	0.00	1.29	0.07	55	7.4	0.7	2.26	A.M.
10	1.38	0.06	1.47	0.00	1.32	0.07	54	7.3	0.7	1.64	A.M.
11	1.41	0.07	1.52	0.00	1.29	0.06	56	7.3	0.7	1.60	J.S.
12	1.42	0.05	1.75	0.00	1.33	0.06	54	7.3	0.7	1.39	J.S.
13	1.43	0.06	1.54	0.00	1.29	0.06	54	7.4	0.7	1.50	A.M.
14	1.52	0.05	1.42	0.00	1.26	0.05	52	7.4	0.7	1.61	A.M.
15	1.43	0.05	1.63	0.00	1.31	0.05	54	7.3	0.7	1.52	J.S.
16	1.43	0.05	1.61	0.00	1.35	0.07	54	7.3	0.7	1.51	J.S.
17	1.44	0.05	1.67	0.00	1.31	0.05	53	7.4	0.7	1.42	J.S.
18	1.44	0.08	1.50	0.00	1.29	0.10	52	7.4	0.8	1.55	A.M.
19	1.43	0.05	1.39	0.00	1.31	0.08	52	7.4	0.7	1.56	A.M.
20	1.44	0.04	1.63	0.00	1.37	0.05	54	7.3	0.7	1.44	J.S.
21	1.44	0.05	1.58	0.00	1.35	0.06	55	7.4	0.7	1.47	J.S.
22	1.36	0.05	1.42	0.00	1.29	0.05	54	7.4	0.7	1.52	A.M.
23	1.49	0.05	1.44	0.00	1.33	0.05	54	7.4	0.7	1.44	A.M.
24	1.41	0.04	1.52	0.00	1.31	0.05	54	7.4	0.7	1.66	A.M.
25	1.4	0.03	1.66	0.00	1.25	0.05	55	7.4	0.7	1.46	J.S.
26	1.18	0.08	1.65	0.00	1.25	0.05	56	7.4	0.7	1.52	J.S.
27	1.32	0.06	1.41	0.00	1.27	0.05	54	7.4	0.7	1.50	A.M.
28	1.41	0.05	1.45	0.00	1.23	0.05	55	7.4	0.7	1.52	A.M.
29	1.39	0.04	1.67	0.00	1.32	0.05	56	7.4	0.7	1.48	J.S.
30	1.36	0.05	1.58	0.00	1.29	0.06	57	7.4	0.7	1.46	J.S.
31											
AVG.	1.40	0.05	1.68	0.00	1.32	0.06	54.67	7.38	0.72	1.66	
MAX.	1.52	0.08	2.26	0.00	1.46	0.1	58	7.4	0.8	2.26	
MIN.	1.18	0.03	1.39	0.00	1.23	0.05	52	7.3	0.68	1.39	

[Redacted Signature]

Ross C. Bostick, Manager of Water Operations
 ROINC - Certification No. 194171377

5/11/2026

Date



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
MAY 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

CHICAGO SUPPLY					DUPAGE DISCHARGE						
DATE	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.37	0.05	1.58	0.00	1.3	0.07	58	7.4	0.7	1.42	J.S.
2	1.43	0.06	1.65	0.00	1.07	0.08	58	7.4	0.7	1.45	K.D.
3	1.35	0.07	1.62	0.00	1.14	0.08	59	7.4	0.7	1.57	K.D.
4	1.37	0.06	1.42	0.00	1.13	0.07	59	7.4	0.7	1.56	J.S.
5	1.41	0.05	1.57	0.00	1.14	0.07	59	7.5	0.7	1.40	J.S.
6	1.36	0.06	1.71	0.00	1.14	0.08	59	7.4	0.7	1.48	K.D.
7	1.27	0.05	1.50	0.00	1.13	0.08	59	7.4	0.7	1.61	K.D.
8	1.3	0.07	1.68	0.00	1.08	0.07	59	7.4	0.7	1.38	K.D.
9	1.26	0.06	1.52	0.00	1.32	0.08	59	7.4	0.8	1.61	R.C.
10	1.43	0.05	1.48	0.00	1.31	0.08	59	7.4	0.8	1.55	R.C.
11	1.35	0.07	1.68	0.00	1.11	0.07	62	7.3	0.7	1.44	K.D.
12	1.44	0.05	1.71	0.00	1.06	0.06	61	7.4	0.7	1.44	K.D.
13	1.47	0.04	1.74	0.00	1.39	0.05	63	7.4	0.7	1.72	R.C.
14	1.39	0.05	1.74	0.00	1.37	0.06	63	7.4	0.8	1.71	R.C.
15	1.34	0.05	1.54	0.00	1.3	0.06	63	7.4	0.7	1.62	R.C.
16	1.28	0.05	1.57	0.00	1.29	0.05	63	7.4	0.8	1.76	R.C.
17	1.34	0.04	1.58	0.00	1.18	0.06	64	7.4	0.7	1.46	K.D.
18	1.27	0.05	1.57	0.00	1.33	0.05	60	7.4	0.7	1.74	R.C.
19	1.38	0.05	1.60	0.00	1.37	0.06	63	7.4	0.7	1.71	R.C.
20	1.45	0.04	1.61	0.00	1.26	0.07	61	7.4	0.7	1.48	K.D.
21	1.48	0.04	1.68	0.00	1.3	0.05	60	7.4	0.7	1.48	K.D.
22	1.29	0.04	1.54	0.00	1.3	0.05	60	7.4	0.8	1.44	K.D.
23	1.41	0.05	1.81	0.00	1.32	0.06	61	7.4	0.8	1.72	R.C.
24	1.29	0.04	1.59	0.00	1.28	0.05	61	7.4	0.8	1.68	R.C.
25	1.27	0.06	1.71	0.00	1.14	0.05	62	7.4	0.7	1.48	K.D.
26	1.31	0.05	1.68	0.00	1.24	0.05	62	7.4	0.7	1.58	K.D.
27	1.45	0.05	1.63	0.00	1.36	0.09	62	7.4	0.7	1.76	R.C.
28	1.35	0.05	1.56	0.00	1.32	0.06	61	7.4	0.7	1.68	R.C.
29	1.4	0.06	1.59	0.00	1.34	0.07	62	7.4	0.7	1.61	R.C.
30	1.35	0.06	1.69	0.00	1.4	0.06	63	7.4	0.7	1.66	R.C.
31	1.31	0.12	1.54	0.00	1.25	0.10	62	7.5	0.7	1.51	A.M.
AVG.	1.36	0.05	1.62	0.00	1.25	0.07	61	7.4	0.7	1.57	
MAX.	1.48	0.12	1.81	0.00	1.4	0.10	64	7.5	0.8	1.76	
MIN.	1.26	0.04	1.42	0.00	1.06	0.05	58	7.3	0.7	1.38	

Ross C. Bostick, Manager of Water Operations
 ROINC - Certification No. 194171377

Date

6/5/2026



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
JUNE 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

CHICAGO SUPPLY					DUPAGE DISCHARGE						
DATE	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.41	0.1	1.72	0.00	1.38	0.07	63	7.4	0.7	1.61	R.C.
2	1.43	0.06	1.58	0.00	1.38	0.06	63	7.4	0.7	1.61	R.C.
3	1.26	0.06	1.38	0.00	1.19	0.14	62	7.5	0.7	1.58	A.M.
4	1.33	0.05	1.42	0.00	1.15	0.13	62	7.5	0.7	1.44	A.M.
5	1.13	0.08	1.41	0.00	1.19	0.08	62	7.5	0.7	1.59	A.M.
6	1.18	0.04	1.60	0.00	1.26	0.06	63	7.5	0.7	1.46	J.S.
7	1.27	0.05	1.46	0.00	1.24	0.07	64	7.5	0.7	1.51	J.S.
8	1.43	0.05	1.51	0.00	1.27	0.07	63	7.5	0.7	1.52	A.M.
9	1.23	0.05	1.37	0.00	1.2	0.05	63	7.5	0.7	1.22	A.M.
10	1.38	0.04	1.53	0.00	1.23	0.05	65	7.5	0.7	1.61	J.S.
11	1.27	0.04	1.59	0.00	1.22	0.07	64	7.5	0.7	1.51	J.S.
12	1.31	0.07	1.57	0.00	1.27	0.07	64	7.5	0.7	1.45	J.S.
13	1.33	0.06	1.51	0.00	1.29	0.06	63	7.5	0.7	1.42	J.S.
14	1.28	0.06	1.55	0.00	1.28	0.06	64	7.4	0.7	1.63	R.C.
15	1.31	0.05	1.53	0.00	1.36	0.06	63	7.5	0.7	1.53	J.S.
16	1.32	0.04	1.62	0.00	1.29	0.06	63	7.5	0.7	1.43	J.S.
17	1.31	0.06	1.71	0.00	1.42	0.06	64	7.5	0.7	1.55	J.S.
18	1.25	0.05	1.53	0.00	1.28	0.06	64	7.4	0.7	1.45	R.C.
19	1.29	0.05	1.72	0.00	1.31	0.06	65	7.5	0.7	1.55	R.C.
20	1.11	0.05	1.71	0.00	1.24	0.07	65	7.5	0.7	1.53	J.S.
21	1.41	0.05	1.71	0.00	1.37	0.08	65	7.5	0.7	1.43	J.S.
22	1.38	0.05	0.98	0.00	1.28	0.06	63	7.5	0.7	1.60	A.M.
23	1.26	0.04	1.55	0.00	1.16	0.06	63	7.5	0.7	1.49	A.M.
24	1.28	0.05	1.62	0.00	1.26	0.06	64	7.5	0.7	1.47	J.S.
25	1.19	0.04	1.45	0.00	1.21	0.05	64	7.5	0.7	1.64	J.S.
26	1.39	0.05	1.55	0.00	1.38	0.06	65	7.5	0.7	1.38	J.S.
27	1.25	0.05	1.65	0.00	1.19	0.06	64	7.4	0.7	1.43	K.D.
28	1.12	0.05	1.61	0.00	1.2	0.05	65	7.4	0.7	1.42	K.D.
29	1.21	0.05	1.65	0.00	1.26	0.07	66	7.5	0.7	1.48	J.S.
30	1.34	0.06	1.50	0.00	1.21	0.06	67	7.5	0.7	1.45	J.S.
31											
AVG.	1.29	0.05	1.54	0.00	1.27	0.07	64	7.5	0.70	1.50	
MAX.	1.43	0.10	1.72	0.00	1.42	0.14	67	7.5	0.74	1.64	
MIN.	1.11	0.04	0.98	0.00	1.15	0.05	62	7.4	0.65	1.22	

Ross C. Bostick, Manager of Water Operations
ROINC - Certification No. 194171377

7/2/2026
Date



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
JULY 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

DATE	CHICAGO SUPPLY				DUPAGE DISCHARGE						
	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.35	0.1	1.75	0.00	1.18	0.09	65	7.4	0.65	1.50	K.D.
2	1.35	0.06	1.46	0.00	1.22	0.07	64	7.4	0.68	1.46	K.D.
3	1.2	0.06	1.67	0.00	1.14	0.07	65	7.4	0.67	1.46	K.D.
4	1.2	0.06	1.59	0.00	1.33	0.08	64	7.4	0.80	1.67	R.C.
5	1.29	0.04	1.59	0.00	1.17	0.06	65	7.4	0.73	1.49	K.D.
6	1.34	0.04	1.74	0.00	1.19	0.06	63	7.4	0.74	1.59	K.D.
7	1.31	0.05	1.55	0.00	1.24	0.06	62	7.4	0.67	1.52	K.D.
8	1.18	0.04	1.56	0.00	1.19	0.05	67	7.4	0.85	1.64	R.C.
9	1.16	0.04	1.48	0.00	1.25	0.07	69	7.4	0.80	1.54	R.C.
10	1.28	0.05	1.56	0.00	1.31	0.05	69	7.5	0.76	1.61	R.C.
11	1.2	0.05	1.59	0.00	1.24	0.08	69	7.5	0.80	1.48	K.D.
12	1.29	0.06	1.71	0.00	1.06	0.07	68	7.4	0.70	1.27	K.D.
13	1.33	0.06	1.71	0.00	1.31	0.07	70	7.5	0.80	1.86	R.C.
14	1.36	0.04	1.55	0.00	1.31	0.06	71	7.5	0.80	1.60	R.C.
15	1.27	0.05	1.74	0.00	1.18	0.09	71	7.4	0.70	1.51	K.D.
16	1.32	0.07	1.65	0.00	1.29	0.10	73	7.4	0.70	1.55	K.D.
17	1.3	0.05	1.76	0.00	1.12	0.06	72	7.4	0.78	1.49	K.D.
18	1.15	0.08	1.80	0.00	1.18	0.07	73	7.5	0.70	1.56	R.C.
19	1.19	0.04	1.65	0.00	1.2	0.05	72	7.5	0.70	1.70	R.C.
20	1.24	0.05	1.73	0.00	1.16	0.04	70	7.5	0.70	1.77	R.C.
21	1.31	0.05	1.46	0.00	1.19	0.06	71	7.4	0.80	1.36	K.D.
22	1.21	0.04	1.61	0.00	1.25	0.05	73	7.5	0.70	1.61	R.C.
23	1.25	0.05	1.58	0.00	1.25	0.05	71	7.5	0.56	1.77	R.C.
24	1.25	0.03	1.68	0.00	1.23	0.05	72	7.6	0.64	1.85	R.C.
25	1.13	0.04	1.45	0.00	1.22	0.09	72	7.5	0.59	1.61	A.M.
26	1.24	0.06	1.24	0.00	1.37	0.06	73	7.5	0.56	1.67	A.M.
27	1.34	0.05	1.79	0.00	1.25	0.05	73	7.5	0.56	1.64	R.C.
28	1.33	0.04	1.38	0.00	1.22	0.06	71	7.5	0.57	1.59	A.M.
29	1.16	0.08	1.59	0.00	1.33	0.09	68	7.5	0.54	1.69	A.M.
30	1.33	0.08	1.39	0.00	1.37	0.10	69	7.6	0.53	1.52	A.M.
31	1.16	0.08	1.63	0.00	1.21	0.09	70	7.6	0.54	1.52	A.M.
AVG.	1.26	0.05	1.60	0.00	1.23	0.07	69	7.5	0.69	1.58	
MAX.	1.36	0.10	1.80	0.00	1.37	0.10	73	7.6	0.85	1.86	
MIN.	1.13	0.03	1.24	0.00	1.06	0.04	62	7.4	0.53	1.27	

 Ross C. Bostick, Manager of Water Operations
 ROINC - Certification No. 194171377

8/7/2026

 Date



DUPAGE WATER COMMISSION
PWS FACILITY ID# - IL435400
MONTHLY OPERATIONS REPORT
AUGUST 2026

DUPAGE WATER COMMISSION LABORATORY BENCH SHEET RESULTS

DATE	CHICAGO SUPPLY				DUPAGE DISCHARGE						
	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	O-PO ₄ (mg/L)	POWDER ACTIVATED CARBON ADDED (LBS/MG)	FREE Cl ₂ (mg/L)	TURBIDITY (ntu)	TEMP (°F)	pH	Fluoride (mg/L)	O-PO ₄ (mg/L)	ANALYST INT.
1	1.23	0.07	1.61	0.00	1.29	0.08	70	7.6	0.5	1.52	J.S.
2	1.35	0.08	1.53	0.00	1.32	0.08	70	7.5	0.5	1.52	J.S.
3	1.16	0.09	1.39	0.00	1.33	0.09	69	7.5	0.5	1.62	A.M.
4	1.22	0.08	1.54	0.00	1.26	0.09	69	7.4	0.5	1.24	A.M.
5	1.31	0.09	1.67	0.00	1.26	0.10	70	7.5	0.6	1.30	J.S.
6	1.18	0.08	1.55	0.00	1.31	0.11	70	7.5	0.5	1.60	J.S.
7	1.31	0.09	1.52	0.00	1.31	0.09	70	7.5	0.5	1.57	J.S.
8	1.24	0.08	1.42	0.00	1.33	0.10	70	7.5	0.5	1.51	J.S.
9	1.23	0.07	1.69	0.00	1.29	0.10	70	7.5	0.6	1.37	R.C.
10	1.31	0.07	1.54	0.00	1.3	0.09	71	7.5	0.5	1.39	J.S.
11	1.22	0.07	1.58	0.00	1.18	0.07	71	7.6	0.5	1.55	J.S.
12	1.35	0.1	1.69	0.00	1.4	0.09	71	7.6	0.6	2.10	J.S.
13	1.34	0.07	1.75	0.00	1.37	0.09	70	7.5	0.6	1.80	R.C.
14	1.14	0.08	1.43	0.00	1.37	0.10	71	7.6	0.5	1.59	A.M.
15	1.34	0.07	1.60	0.00	1.38	0.07	71	7.6	0.5	1.61	J.S.
16	1.2	0.08	1.68	0.00	1.32	0.07	70	7.6	0.5	1.62	J.S.
17	1.29	0.07	1.57	0.00	1.38	0.08	69	7.5	0.5	1.69	A.M.
18	1.31	0.08	1.54	0.00	1.33	0.08	69	7.5	0.5	1.66	A.M.
19	1.21	0.07	1.80	0.00	1.37	0.07	70	7.5	0.5	1.61	J.S.
20	1.24	0.05	1.63	0.00	1.32	0.06	71	7.6	0.5	1.79	J.S.
21	1.29	0.06	1.67	0.00	1.26	0.07	72	7.6	0.5	1.72	J.S.
22	1.24	0.05	1.64	0.00	1.3	0.07	72	7.6	0.5	1.61	J.S.
23	1.19	0.05	1.64	0.00	1.25	0.07	73	7.6	0.6	1.65	K.D.
24	1.13	0.06	1.64	0.00	1.18	0.07	72	7.6	0.4	1.75	J.S.
25	1.34	0.07	1.76	0.00	1.15	0.07	72	7.6	0.4	1.65	J.S.
26	1.27	0.05	1.55	0.00	1.03	0.06	73	7.6	0.5	1.44	K.D.
27	1.27	0.05	1.76	0.00	1.32	0.06	73	7.6	0.5	1.72	K.D.
28	1.13	0.06	1.68	0.00	1.14	0.07	73	7.6	0.4	1.59	K.D.
29	1.3	0.05	1.63	0.00	1.25	0.07	73	7.6	0.5	1.69	R.C.
30	1.29	0.06	1.69	0.00	1.32	0.06	73	7.5	0.5	1.76	A.M.
31	1.15	0.06	1.73	0.00	1.07	0.06	73	7.6	0.5	1.52	K.D.
AVG.	1.25	0.07	1.62	0.00	1.28	0.08	71	7.6	0.5	1.61	
MAX.	1.35	0.10	1.80	0.00	1.4	0.11	73	7.6	0.6	2.10	
MIN.	1.13	0.05	1.39	0.00	1.03	0.06	69	7.4	0.4	1.24	

Ross C. Bostick, Manager of Water Operations
 ROINC - Certification No. 194171377

9/4/2026

Date